



**NOTES:**

1. ALL BLOCKING AND WOOD POST SHALL REST ON UNDISTURBED SOIL.
2. HYDRANT TO BE SUPPLIED BY RATNIK INDUSTRIES OR APPROVED EQUAL (SEE SPECIFICATIONS).
3. ALL DIMENSIONS ARE IN MILLIMETRES.
4. REMOVEABLE HYDRANT WRENCH (OR 'KEY') TO BE PROVIDED TO COMMUNITY SERVICES AFTER DEMONSTRATION OF HYDRANT FUNCTIONING, PRIOR TO ISSUANCE OF PRELIMINARY ACCEPTANCE.

**NO. REVISION**

**DATE**

1. MINOR NOTES REVISION 01MAR02
2. ADD NOTE #4 (SEE SPEC) 29JAN03
3. ADD TAMPER RESISTANT TOP 26SEPT05



SCALE: N.T.S.  
 DATE: 1 MARCH 2002  
 DRAWN BY: P & D  
 NUMBER: 15430-1

**YARD HYDRANT**