

- 1. FLEXIBLE AND COMPOSITE PAVEMENT SHALL BE 5mm ABOVE THE ADJACENT EDGE OF GUTTER.
- 2. WHERE THE SIDEWALK IS CONTINUOUS TO THE CURB, AT ENTRANCES LOWER THE HEIGHT OF THE ADDITIONAL CONCRETE AT THE REAR OF THE CURB TO 150mm.
- 3. FOR SLIPFORMING PROCEDURE, A 5% BATTER IS ACCEPTABLE.
- 4. TREATMENT AT ENTRANCES SHALL CONFORM WITH OPSD-351.01.
- 5. OUTLET TREATMENT SHALL CONFORM WITH OPSD-610 SERIES.
- 6. THE LENGTH OF TRANSITION FROM ONE CURB TYPE TO ANOTHER SHALL BE 3.0m, EXCEPT IN CONJUNCTION WITH GUIDE RAIL, IT SHALL CONFORM TO OPSD-900 SERIES.
- 7. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.
- 8. BASE CURB IS TO BE FLUSHED THEN BLOWN OFF WITH HIGH PRESSURE AIR TO ENSURE A CLEAN DRY SURFACE.
- 9. ALL CONCRETE CSA, C-2, 32MPa.



STANDARD

CONCRETE BARRIER CURB
WITH STANDARD GUTTER
TWO STAGE CONSTRUCTION

EFF. DATE		2015-12-11	SCALE	N.T.S.
REV.		2016-09-21	STANDARD No.	2230.010