



MATCH TO EXISTING GRADE

TREE TIES TO BE FASTENED AROUND THE TREE ABOVE LOWER BRANCHES IN FIGURE EIGHT WITH NO. 9 GAL. SUPPORT WIRE ENCASE IN 13mm DIA. 2-PLY RUBBER HOSE TIGHTLY COILED AND TRIM ENDS OF WIRE

37 mm x 37 mm x 2.1m STEEL T-BARS DRILLED TO RECEIVE GUY WIRES. BARS TO BE TREATED TO PREVENT RUST AS SPECIFIED IN PLANTING PLAN AND SUNK FIRMLY INTO SUBSOIL

DEPTH OF PLANTING PIT TO BE APPROVED BY COMMUNITY SERVICES REPRESENTATIVE

SHREDDED BARK MULCH LAYER TO A MINIMUM 75mm DEPTH

EARTH SAUCER MIN 100mm HIGH AROUND EXCAVATED AREA

CUT AND REMOVE 1/3 OF BURLAP FOLD BACK AND BURY

TREE PIT TO BE EXCAVATED AS PER SPECIFICATIONS

BLEND IN GRADES AT 2:1 MAX

UNDISTURBED SUBSOIL

**NOTES:**

1. ALL PLANTING SHALL BE DONE UNDER THE DIRECTION AND SUPERVISION OF PERSONNEL WITH AT LEAST 5 YRS HORTICULTURAL AND PLANTING EXPERIENCE AND CONFORM TO BEST HORTICULTURAL PRACTICES
2. SAMPLES OF MULCH, TOP SOIL AND TREE ACCESSORIES MUST BE SUBMITTED TO COMMUNITY SERVICES FOR APPROVAL
3. PLANTING OF PLANT MATERIAL PRIOR TO COMMUNITY SERVICES APPROVAL WILL BE AT THE CONTRACTORS RISK. COMMUNITY SERVICES RESERVES THE RIGHT TO REJECT PLANT MATERIAL THAT DOES NOT CONFORM TO PLANTING PLAN SPECIFICATIONS
4. ONLY USE IMPORTED TOPSOIL WHEN TOPSOIL FROM SITE HAS BEEN DEPLETED OR IS UNACCEPTABLE TO COMMUNITY SERVICES
5. PLANTS SHALL BE SOUND HEALTHY, VIGOROUS AND WELL BRANCHED. THEY SHALL BE FREE OF INSECT PESTS' EGGS AND LARVAE AND SHALL HAVE HEALTHY WELL DEVELOPED ROOT SYSTEMS
6. KEEP ALL PLANTS WATERED FROM TIME OF PLANTING UNTIL ACCEPTANCE

**NO. REVISION**

**DATE**



SCALE: N.T.S.  
 DATE: JANUARY 2001  
 DRAWN BY: P & D  
 NUMBER: 02950-7

**TYPICAL TREE PLANTING ON SLOPE**