— SAW CUT EXIST. ASPH. -50mm HL3 150mm GRAN."A" -MATCH BASE ASPHALT TYPE 300mm 300mm AND THICKNESS OR CONCRETE GRAN."B" MATCH GRANULAR 'B' THICKNESS WITH A MINIMUM DEPTH OF 300mm UNDERSIDE OF UNSHRINKABLE FILL UNSHRINKABLE FILL MUST BE A MINIMUM OF 1200 mm FROM ⊿ ′⊿ SURFACE Δ Δ BEDDING AS PER UTILITY VARIES REQUIREMENTS **VARIES**

NOTES

- I. ALL GRANULAR MATERIALS SHALL BE COMPACTED TO 98% STANDARD PROCTOR DENSITY AT OPTIMUM WATER CONTENT
- 2. UNSHRINKABLE FILL TO EXTEND FROM TOP OF UTILITY BEDDING TO BOTTOM OF GRANULAR "B"
- 3. SEE NOTES ON STD. 2220.032 FOR ADDITIONAL DETAILS
- 4.GRANULAR "A" TO BE OPSS 1010 19mm CRUSHER RUN LIMESTONE
- 5.GRANULAR "B" TO BE OPSS 1010 TYPE 2 50mm CRUSHER RUN LIMESTONE



METRIC

ALL DIMENSIONS IN MILLIMETRES

STANDARD TRENCH RESTORATION FOR OPEN CUT UTILITY INSTALLATION UNDER ROADWAYS

EFF. DATE		2002-01-01	SCALE	N.T.S.
REV.	5	2022-09-27	STANDARD No.	2220.030