



NOTES

1. DROP PIPE TO BE USED IN ALL MANHOLES WHERE DIFFERENCE IN OBVERT ELEVATION EXCEEDS 1200mm OR AS PIPE SIZE PERMITS
2. STORM SEWER DROP PIPE TO BE 0.5 OF THE INLET PIPE DIA. (MAX. DIA. 450mm-MIN. DIA. 250mm)
3. SPRINGLINE OF DROP PIPE TO BE THE SAME ELEVATION AS SPRINGLINE OF OUTLET PIPE



MISSISSAUGA
Transportation and Works

STANDARD

DROP PIPE FOR MANHOLES

EFF. DATE	2002-01-01	SCALE	N.T.S.
REV.		STANDARD No.	2113.010