



NOTES:

1. STORM & SANITARY SERVICE CONNECTIONS MAY BE INSTALLED IN A COMMON TRENCH PROVIDED WIDTH DOES NOT EXCEED SUM OF O.D.'S + 500mm.
2. WATER SERVICE IS TO BE LOCATED A MIN. OF 244mm HORIZ. OR FROM NEAREST WATER SERVICE OR IN ACCORDANCE WITH THE ONTARIO BUILDING CODE.
3. WHERE A LOT IS SUBJECT TO AN EASEMENT FOR STORM SEWER, SANITARY SEWER OR WATERMAIN THE INTERIOR LIMIT OF THE EASEMENT WILL BE CONSIDERED THE LOT LINE FOR SERVICE PURPOSES.



STANDARD
LOCATION OF SERVICES
SEMI-DETACHED
RESIDENTIAL LOT

EFF. DATE	2002-01-01	SCALE	N.T.S.
REV.		STANDARD No.	2115.020