



NOTES:

1. STORM & SANITARY SERVICE CONNECTIONS MAY BE INSTALLED IN A COMMON TRENCH PROVIDED WIDTH DOES NOT EXCEED SUM OF O.D.'S + 500mm.
2. WATER SERVICE IS TO BE LOCATED A MIN. OF 1500mm FROM NEAREST SEWER SERVICE.
3. WHERE A LOT IS SUBJECT TO AN EASEMENT FOR STORM SEWER, SANITARY SEWER OR WATERMAIN THE INTERIOR LIMIT OF THE EASEMENT WILL BE CONSIDERED THE LOT LINE FOR SERVICING PURPOSES. IF AN EASEMENT IS REQUIRED WHERE THE DOUBLE SANITARY & STORM SERVICES ARE TO BE PLACED STANDARD 2115.010 MUST BE USED.
4. THE HYDRO, BELL, CATV & GAS CORRIDORS MAY BE SUPERIMPOSED ONTO THE SANITARY, STORM & WATER CORRIDOR, IF THE BUILDING CONSTRUCTION DICTATES & AS APPROVED BY THE COMMISSIONER OF TRANSPORTATION AND WORKS.



**STANDARD
LOCATION OF SERVICES
SINGLE FAMILY RESIDENTIAL LOTS
WHERE DOUBLE SANITARY & STORM
HOUSE CONNECTIONS ARE USED**

EFF. DATE	2002-01-01	SCALE	N.T.S.
REV.		STANDARD No.	2115.030