

## **LEGEND**

- EDGE OF PAVEMENT

- CATCH BASIN

CURB - CURB OR CURB AND GUTTER

- CENTRELINE

- GAS MAIN

- FIRE HYDRANT

HYDV - FIRE HYDRANT VALVE

PWV - PRIVATE WATER VALVE

- PROPERTY LINE - STREETLIGHT SL

SW - SIDEWALK

SAN - SANITARY SEWER

STM- STORM SEWER

- UTIITY BOX (HYDRO, TELECOMMUNICATIONS) - UTILITY CORRIDOR (HYDRO, TELECOMM, GAS, SL) UC

IJР - UTILITY POLE

WM - WATERMAIN

- HYDRO, TELECOMMUNICATIONS, GAS AND SL CORRIDOR TO HAVE A MINIMUM COVER OF 0.965 m.
- 2. WATERMAIN TO HAVE A MINIMUM COVER OF 1.7m.
- 3. IF UTILITIES CANNOT BE INSTALLED ACCORDING TO THIS STANDARD THEY ARE TO BE INSTALLED AS CLOSE AS POSSIBLE TO THE PRESCRIBED LOCATION SUBJECT TO THE APPROVAL OF THE TRANSPORTATION AND WORKS DEPARTMENT OF THE CITY OF MISSISSAUGA.
- 4. A 0.4m 0.6m CLEARANCE MUST BE MAINTAINED BETWEEN CABLES AND HYDRANTS
- 5. A 0.3m CLEARANCE MUST BE MAINTAINED BETWEEN WATERMAINS AND UTILITY POLES.
- 6. PAVEMENT WIDTH IS MEASURED FROM FACE OF CURB TO FACE OF CURB IN ACCORDANCE TO OPSD STD 600.05
- 7. ROAD WIDTH IS MEASURED FROM FACE OF CURB TO FACE OF CURB AS DEFINED IN OPSD STD. 6000.040 CURB & GUTTER. PAVEMENT WIDTH IS MEASURED FROM EDGE OF PAVEMENT (EP) TO EDGE OF PAVEMENT (EP).
- 8. FOR LOCATION OF GAS MAIN WITHIN UTILITY CORRIDOR REFER TO STD. 2211.280
- 9. HYDRO TRANSFORMERS AND UTILITY BOXES SHALL BE LOCATED ON PRIVATE PROPERTY OR UNDERGROUND WITHIN THE BOULEVARD AREA IN A LOCATION APPROVED BY THE COMMISIONER OF TRANSPORTATION AND WORKS.

## **METRIC**

ALL DIMENSIONS IN METRES



## **STANDARD CROSS SECTION SPECIFIC** TO CITY CENTRE 14.5m ROAD ON 26m ROW

EFF. DATE		2003-01-22	SCALE	N.T.S.
REV.			STANDARD No.	2211.153