



NOTES:

1. FLEXIBLE AND/OR COMPOSITE PAVEMENT SHALL BE 5mm ABOVE THE ADJACENT EDGE OF GUTTER.
2. FOR SLIPFORMING PROCEDURE, A 5% BATTER IS ACCEPTABLE.
3. MAIN-LINE CURB SHALL BE SAW CUT VERTICALLY AT EXPANSION JOINT LOCATION TO PROVIDE A SMOOTH VERTICAL SURFACE TO FLUSHLY MOUNT THE EXPANSION JOINT MATERIAL
4. TREATMENT AT ENTRANCES SHALL CONFORM WITH OPSD-351.01.
5. OUTLET TREATMENT SHALL CONFORM WITH OPSD-610 SERIES.
6. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.



FULL STAGE  
CONCRETE CURB  
AT CATCHBASIN

EFF. DATE		SCALE	N.T.S.
REV.	1	2019-04-02	STANDARD No. 2230.011