

NOTES

1.) THIS PEDESTAL WILL INCLUDE SECURELY HOUSED, SUITABLY SIZED CIRCUIT BREAKERS, 1- 60 AMP DOUBLE POLE BREAKER, 1- 40 AMP BREAKER, 1- 50 AMP BREAKER, AS PER 2060.07


2.) ALL MATERIAL GALVANIZED FINISH

3.) CONCRETE BASE TO BE 1200mm DEEP

4.) ALL P.V.C. CONDUIT TO BE MIN. 600mm DEEP

METRIC

ALL DIMENSIONS IN MILLIMETRES

 MISSISSAUGA <i>Transportation and Works</i>			
STANDARD TYPICAL POWER SUPPLY MOUNTING DETAIL FOR POWER SERVICE PEDESTAL (POWCO 8500 SERIES OR EQUAL)			
EFF. DATE	03-02	SCALE	N.T.S.
REV.	1	26/02/03	STANDARD No. 2600.016