

- GRANULAR MATERIAL IS TO BE CLEAN APPROVED MATERIAL AND PLACED AT NOTED DIMENSIONS PRIOR TO LAND DISTURBANCE
- GEOTEXTILE IS TO BE PLACED OVER THE ENTIRE AREA PRIOR TO STONE PLACEMENT
- MAINTENANCE- THE ENTRANCE SHALL BE
  MAINTAINED IN A CONDITION WHICH WILL REDUCE
  TRACKING OR FLOWING OF SEDMENT ONTO THE
  R.O.W. AND GRANULAR MATERIAL IS TO BE REPLACED
  AS WARRANTED OR DIRECTED BY THE TRANSPORTATION
  AND WORKS DEPARTMENT OF THE CITY OF MISSISSAUGA.
- FOR SITE DEVELOPMENTS GREATER THAN 4.0hg IN SIZE 20m (MIN) IS REQUIRED FOR 50mm CLEAR STONE AND IOM (MIN) IS REQUIRED FOR 150mm RIP RAP.

## Transportation and Works

STANDARD

CONSTRUCTION ENTRANCE STONE PAD

EFF. DATE 2002-01-01 SCALE STANDARD No. N.T.S 2970.010

REV.