



**NOTES:**

1. ALL STREETLIGHTING INSTALLATIONS ARE OWNED BY THE CITY OF MISSISSAUGA, UNLESS OTHERWISE SPECIFIED.
2. FOR STREETLIGHT CABLES IN JOINT USE TRENCH, SEE THE FOLLOWING E.H.M. STANDARDS:

37-140	TYPICAL PLANNED SEPARATION UTILITY CABLES AT 2.7 m FROM PROPERTY LINE AND IN A 1016 mm (40") JOINT USE TRENCH WITH GAS
37-142B	TYPICAL PLANNED SEPARATION UTILITY CABLES IN A 762 mm (30") JOINT USE TRENCH (1 - MAIN FEEDER AND 1 - DISTRIBUTION FEEDER)
37-142D	TYPICAL PLANNED SEPARATION UTILITY CABLES IN A 610 mm (24") JOINT USE TRENCH (1 - MAIN FEEDER AND 1 - DISTRIBUTION FEEDER)
37-142E	TYPICAL PLANNED SEPARATION UTILITY CABLES IN A 610 mm (24") JOINT USE TRENCH (1 - MAIN FEEDER AND 2 - DISTRIBUTION FEEDER)
37-143	TYPICAL PLANNED SEPARATION UTILITY CABLES IN A 762 mm (30") JOINT USE TRENCH - TOWNHOUSES

3. FOR DRIVEWAYS, BACKFILL SHALL BE GRANULAR "A".

METRIC/IMPERIAL

DIMENSIONS SHOWN IN METRIC AND IMPERIAL UNITS



**MISSISSAUGA**  
Leading today for tomorrow

STANDARD

STREETLIGHTING - SEPARATION &  
TRENCH REQUIREMENTS FOR  
STREETLIGHTING ONLY

EFF. DATE	2002-01-01	SCALE	N.T.S.
REV.		STANDARD No. 3100.220	