POWER PEDESTAL IS OFFSET 2.0m FROM PROPERTY LINE AND 2.0m FROM PATHWAY EDGE

**KEY** 

- ELECTRICAL HANDWELL IS TO BE OFFSET 1.0m FROM THE PROPERTY LINE SEE DETAIL 16530-7
- PATHWAY POLE IS TO BE OFFSET 0.60m FROM PATHWAY EDGE
  - CONDUIT IS OFFSET 1.0m FROM PATHWAY EDGE

## PROPERTY SIDEWALK CURB **PATHWAY** B -12.0m A 1.0m 9 35.0m MAX. **-**1.0m

GRADE 300 CLEAN FILL COMPACTED TO 98% S.P.D. 150mm WIDE YELLOW PLASTIC CAUTION TAPE CONTINUOUS ABOVE WIRING PARK LIGHTING CABLES IN 38mm DIA. POLYETHYLENE PIPE-2-#4 OR 2-#6 AND 1-#6 T.W.U. 150 OF SAND BACKFILL

GRADE 150mm WIDE YELLOW PLASTIC CAUTION TAPE CONTINUOUS ABOVE WIRING 38mm DIA. POLYETHYLENE PIPE SLEEVED THROUGH BELOW GRADE APERTURE

SECTION (A) - (A) TRENCH CONDUIT

150 to 200

SECTION (B) - (B) LIGHT POLE

### NOTES:

1. REFER TO ASPHALT PEDESTRIAN PATHWAY DETAIL NO. 02510-1
FOR PATHWAY DETAIL. THE COMMUNITY SERVICES - SUBDIVISION
REQUIREMENTS MANUAL CONTAINS THE ASSOCIATED ELECTRICAL
DETAILS AND STANDARDS.
2. TRENCH TO BE SET BACK 1000mm FROM PATHWAY EDGE.
3. LIGHT POLE TO BE SET BACK 600mm FROM PATHWAY EDGE.
4. POWER PEDESTAL TO BE SET BACK 2000mm FROM PATHWAY EDGE
AND 2000mm FROM PROPERTY LINE.
5. POLE SPACING IS TO BE DETERMINED BY A CERTIFIED
ELECTRICAL ENGINEER.
6. ELECTRICAL CONNECTION TO BE MADE IN HANDWELL BY
ENERSOURCE AFTER E.S.A. APPROVAL.
7. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE
NOTED.

8. ARRANGE INSPECTIONS OF WORK PER SPECIFICATION.

### NO. REVISION

1. MAR29/04 - HANDWELL & CAUTIÓN TAPE

# Community Services

SCALE: N.T.S. DATE: March 29, 2004 DRAWN BY: P & D NUMBER: 16530-3

DATE