

ELEVATION



SECTION



GENERAL NOTES:

1. Detail to be To be reviewed and approved by structural engineer.

CONCRETE NOTES:

- Do concrete materials and methods of concrete construction in accordance with structural engineering
- drawings.
- Contractor to verify accuracy of concrete details and reinforcement prior to installation.
- For construction materials refer to structural engineering drawings and specifications.
- 4. Concrete mix to provide compressive strength of 28MPA at 28 days, entrained air of 6% to 1% and slump at point of discharge of 60mm, or as per structural engineering drawings and specifications.
- Pour concrete in favorable weather conditions. Inform the landscape architect of any adverse weather impacts prior to pouring.
- 6. Pour concrete in uniform layers of continuous lengths between expansion joints. An expansion joint is required where placing has been suspended for 30 minutes.
 7. Provide control joints at 4500 c/c maximum and expansion joints at 9000 c/c maximum unless noted otherwise. See typical construction details for control and expansion joint
- Surface finish of planter is to be an architectural finish with the use of form liners.
- Repair defective areas while concrete is still plastic, or remove defective work and replace with new concrete.
 Concrete areas will not be accepted if:
- .1 fails to meet requirements of this specification
 .2 contains excessive honeycombing or embedded debris
 .3 28 days average strength in any defined area is less
- .3 28 days average strength in any defined area is less than 95% of specified minimum strength..4 surface irregularities..5 damaged or chipped.
- .6 poor workmanship.11.1t is the contractor's responsibility to maintain and protect concrete areas until time of final acceptance.

L-5

NOT FOR CONSTRUCTION

ISSUED FOR REVIEW & COMMENTS ONLY

REVISIONS/ SUBMISSIONS

DATE DESCRIPTION

1 2021-10-29 Issued for coordination
2 2021-11-05 Issued for coordination

3 2021-11-11 Issued for submission

__



Branthaven Ninth Line Inc.

MUNICIPALITY

City of Mississauga

PROJECT 5160-5170 Ninth Line

MUNICIPAL FILE NUMBER

SHEET

Details

L-5

adesso design inc.
landscape architecture



1.8m HT Wood Privacy Fence

SCALE: NTS

Cast-In-Place Concrete Raised Planter

Scale: NTS