

HYDROGEOLOGICAL REVIEW REPORT

PREPARED FOR:

ACLP - Dundas Street E
25 Watline Ave. Suite 501
Mississauga ON, L4Z 2Z1

ATTENTION:

Jodi Shpigel

**60 Dundas St E | Mississauga,
Ontario**

Grounded Engineering Inc.

File No. 21-067

Issued February 24, 2022



Executive Summary

Grounded Engineering Inc. (Grounded) was retained by ACLP - Dundas Street E to conduct a Hydrogeological Review for the proposed redevelopment of 60 Dundas St E in Mississauga, Ontario. The conclusions of the investigation are summarized as follows:

Development Information

Current Development					
Development Phase	Above Grade Levels	Below Grade Levels			
		Level #	Lowest Finished Floor		Approximate Base of Footings (masl)
			Depth (m)	Elevation (masl)	
60 Dundas St E	1	0	0	111.0 (approx.)	Unknown

Proposed Development					
Development Phase	Above Grade Levels	Below Grade Levels			
		Level #	Lowest Finished Floor		Approximate Base of Footings (masl)
			Depth (m)	Elevation (masl)	
60 Dundas St E – Tower A	40				
60 Dundas St E – Tower B	35	P5	17	94.0 (approx.)	93.0 (approx.)
60 Dundas St E – Tower C	32				

Site Conditions

Site Stratigraphy				
Stratum/Formation	Aquifer or Aquitard	Depth Range (mbgs)	Elevation Range (masl)	Hydraulic Conductivity (m/s)
Earth Fill	Aquifer	0.1 – 4.0	110.8 – 106.0	$1.0 \times 10^{-5**}$
Clayey Silt Glacial Till	Aquitard	1.7 – 6.3	108.9 – 103.9	$4.1 \times 10^{-8*}$
Weathered Bedrock	Aquifer	6.1 – 6.3***	104.6 – 103.5***	$1.0 \times 10^{-7**}$
Sound Bedrock	Aquitard	Below 6.3***	Below 103.5***	$1.0 \times 10^{-8**}$

*Indicates conductivity was calculated by geometric mean of Slug Test

** Indicates conductivity was estimated using typical published values from Freeze and Cherry (1979) and knowledge of adjacent site conditions

***Inferred based on drilling observations. To be confirmed through additional rock coring at a later date

Maximum Groundwater Elevation		
Monitoring Well ID	Depth Below Grade (m)	Elevation (masl)
101	3.2	107.7
102	3.8	106.2
103	4.0	105.4



Groundwater Quality				
Sample ID	Sample Date	Sample Expiry Date	City of Mississauga Storm Sewer Limits	Region of Peel Sanitary Sewer Limits
SW-UF-BH101	10 May 2021	10 Feb 2022	Exceeds	Meets

Groundwater Control

Stored Groundwater (pre-excavation/dewatering)					
Volume of Excavation (m ³)	Volume of Excavation Below Water Table (m ³)	Volume of Stored Groundwater		Volume of Available Groundwater	
		(m ³)	(L)	(m ³)	(L)
180,264	148,109	13,300	13,300,000	8,700	8,700,000

Short Term (Construction) Groundwater Quantity – Safety Factor of 1.5 Used					
Groundwater Seepage		Design Rainfall Event (25mm)		Total Daily Water Takings	
L/day	L/min	L/day	L/min	L/day	L/min
10,000	6.9	244,000	169.4	254,000	176.4

Long Term (Permanent) Groundwater Quantity – Safety Factor of 1.5 Used					
Groundwater Seepage		Infiltration Design Rainfall Event (25mm)		Total Daily Water Takings	
L/day	L/min	L/day	L/min	L/day	L/min
10,000	6.9	21,000	14.6	31,000	21.5

Regulatory Requirements	
Environmental Activity and Sector Registry (EASR) Posting	Required
Short Term Permit to Take Water (PTTW)	Not Required
Long Term Permit to Take Water (PTTW)	Not Required
Short Term Discharge Agreement City of Mississauga/Region of Peel	Required
Long Term Discharge Agreement City of Mississauga/Region of Peel	Required



TABLE OF CONTENTS

1	INTRODUCTION	1
2	STUDY AREA MAP	3
3	GEOLOGY AND PHYSICAL HYDROGEOLOGY	3
4	MONITORING WELL INFORMATION.....	4
5	GROUNDWATER ELEVATIONS.....	4
6	AQUIFER TESTING	4
6.1	SINGLE WELL RESPONSE TEST (SLUG TEST)	4
6.2	SOIL GRAIN SIZE DISTRIBUTION	5
6.3	LITERATURE.....	5
7	WATER QUALITY.....	6
8	PROPOSED CONSTRUCTION METHOD.....	6
9	PRIVATE WATER DRAINAGE SYSTEM (PWDS).....	7
10	GROUNDWATER EXTRACTION AND DISCHARGE	7
11	EVALUATION OF IMPACT	9
11.1	ZONE OF INFLUENCE (ZOI).....	9
11.2	LAND STABILITY.....	10
11.3	CITY'S SEWAGE WORKS	10
11.4	NATURAL ENVIRONMENT	11
11.5	LOCAL DRINKING WATER WELLS	11
11.6	CONTAMINATION SOURCE.....	11
12	PROPOSED MITIGATION MEASURES AND MONITORING PLAN	11
13	LIMITATIONS	12
13.1	REPORT USE.....	12
14	CLOSURE.....	12



FIGURES

Figure 1 – Study Area Map

Figure 2 – Borehole and Monitoring Well Location Plan

Figure 3 – Hydrological Cross-Section

APPENDICES

Appendix A – Borehole Logs

Appendix B – Aquifer Response Tests

Appendix C – Grain Size Analysis

Appendix D – HydrogeoSieveXL Data

Appendix E – Laboratory Certificate of Analysis

Appendix F – Finite Element Model

Appendix G – Dewatering Calculations



1 Introduction

ACLP - Dundas Street E has retained Grounded Engineering Inc. ("Grounded") to provide hydrogeological engineering design advice for their proposed development at 60 Dundas St E, in Mississauga, Ontario.

Property Information

Location of Property	60 Dundas St E, Mississauga, Ontario, L5A 1W4
Ownership of Property	Gold Star Plaza Ltd.
Property Dimensions (m)	110 x 114 (irregular shape)
Property Area (m ²)	10,724

Existing Development

Number of Building Structures	1
Number of Above Grade Levels	1
Number of Underground Levels	0
Sub-Grade Depth of Development (m)	0
Sub-Grade Area (m ²)	0
Land Use Classification	Commercial

Proposed Development

Number of Building Structures	3
Number of Above Grade Levels	Building A = 40 Building B = 35 Building C = 32
Number of Underground Levels	5
Sub-Grade Depth of Development (m)	17
Sub-Grade Area (m ²)	9,685
Land Use Classification	Residential



Qualified Person and Hydrogeological Review Information

Qualified Person	Matthew Bielaski, P.Eng., QP _{ESA-RA}
Consulting Firm	Grounded Engineering Inc.
Date of Hydrogeological Review	February 24, 2022
Scope of Work	<ul style="list-style-type: none"> ▪ Review of MECP Water Well Records for the area ▪ Review of geological information for the area ▪ Review of topographic information for the area ▪ Advancement of 3 boreholes to a depth of 5.1 to 7.4 m, which were instrumented with monitoring wells ▪ Completion of slug tests in all available monitoring wells ▪ Ground water elevation monitoring once after drilling and once at least three months after to capture seasonal fluctuations ▪ Ground water sampling and analysis to the City of Mississauga and Region of Peel Sewer Use Limits ▪ Assessment of groundwater controls and potential impacts ▪ Report preparation in accordance with Ontario Water Resources Act, Ontario Regulation 387/04

General Hydrogeological Characterization

Property Topography	The site has an approximate ground surface elevation of 111.0 masl.
Local Physiographic Features	The site is composed of earth fill and clayey silt till.
Regional Physiographic Features	The West St Lawrence Lowland consists of a limestone plain (elevation 200–250 masl) that is separated by a broad, shale lowland from a broader dolomite and limestone plateau west of Lake Ontario. This plateau is bounded by the Niagara Escarpment. From the escarpment the plateau slopes gently southwest to lakes Huron and Erie (elevation 173 masl). Glaciation has mantled this region with several layers of glacial till (i.e., an unsorted mixture of clay, sand, etc.), the youngest forming extensive, undulating till plains, often enclosing rolling drumlin fields.
Watershed	The site is located within the Credit River Watershed. Locally, groundwater is anticipated to flow southeast towards Lake Ontario.
Surface Drainage	Surface water is expected to flow towards municipal catch basins located on the site.



2 Study Area Map

A map has been enclosed which shows the following information:

- All monitoring wells identified on site
- All monitoring wells identified off site within the study area
- All boreholes identified on site
- All buildings identified on site and within the study area
- The property boundaries of the site
- Any watercourses and drainage features within the study area.

3 Geology and Physical Hydrogeology

The site stratigraphy, including soil materials, composition and texture are presented in detail on the borehole logs in Appendix A. A summary of stratigraphic units that were encountered at the site are as follows:

Site Stratigraphy				
Stratum/Formation	Aquifer or Aquitard	Depth Range (mbgs)	Elevation Range (masl)	Hydraulic Conductivity (m/s)
Earth Fill	Aquifer	0.1 – 4.0	110.8 – 106.0	1.0×10^{-5}
Clayey Silt Glacial Till	Aquitard	1.7 – 6.3	108.9 – 103.9	4.1×10^{-8}

Bedrock			
Stratum	Depth Range (mbgs)	Elevation Range (masl)	Hydraulic Conductivity (m/s)
Weathered	6.1 – 6.3*	104.6 – 103.5*	1.0×10^{-7}
Sound	Below 6.3*	Below 103.5*	1.0×10^{-8}

* Inferred based on drilling observations. To be confirmed through additional rock coring at a later date

Surface Water		
Surface Water Body	Distance from site (m)	Hydraulically Connected to Property (yes/no)
Cooksville Creek	Adjacent to east boundary of site	No – the creek has been channelized hydraulically cut off from the site by a concrete retaining wall



4 Monitoring Well Information

Well ID	Well Diameter (mm)	Ground Surface (masl)	Top of Screen (masl)	Bottom of Screen (masl)	Screened Geological Unit
101	50	110.9	106.3	104.8	Clayey Silt Glacial Till
102	50	110.0	105.4	103.9	Clayey Silt Glacial Till
103	50	109.4	106.0	104.5	Clayey Silt Glacial Till

5 Groundwater Elevations

Well ID	Groundwater Elevation (masl)			
	May 4, 2021	May 6, 2021	May 10, 2021	May 21, 2021
101	106.2	107.4	107.6	107.7
102	105.3	106.0	106.2	106.2
103	104.8	105.3	105.3	105.4

The groundwater table fluctuates from about 3.2 to 4.7 metres below grade, in the clayey silt till at Elev. 104.8 to 107.7 m with the groundwater sloping downwards from the west to the east towards Cooksville Creek. For design purposes, the groundwater table is assumed to be at Elev. 107.7 m. This deposit has a very low permeability and will yield only minor seepage in the long term. There is also water within discrete fractures in the bedrock.

Groundwater levels fluctuate with time depending on the amount of precipitation and surface runoff and may be influenced by known or unknown dewatering activities at nearby sites.

6 Aquifer Testing

6.1 Single Well Response Test (Slug Test)

The hydraulic conductivities from the monitoring wells were determined based on slug tests (single-well response tests). These tests involve rapid removal of water or addition of a “slug” which displaces a known volume of water from a single well, and then monitoring the water level in the well until it recovers. The results of the slug tests were analyzed using the Bouwer and Rice method (1976).

The hydraulic properties of the strata applicable to the site are as follows:



Well ID	Well Screen Elevation (masl)	Screened Geological Unit	Hydraulic Conductivity (m/s)
101	106.3 - 104.8	Clayey Silt Till	6.8×10^{-8}
102	105.4 - 103.9	Clayey Silt Till	1.7×10^{-8}
103	106.0 - 104.5	Clayey Silt Till	6.2×10^{-8}

A design hydraulic conductivity value of 4.1×10^{-8} m/s was used for the clayey silt till unit as a product of the geometric mean of the three hydraulic conductivity measurements achieved from the well response tests conducted.

6.2 Soil Grain Size Distribution

The hydraulic conductivities of various soil types can also be estimated from grain size analyses. An assessment of the grain sizes was conducted using the excel-based tool, HydrogeoSieve XL (*HydrogeoSieve XL ver.2.2, J.F. Devlin, University of Kansas, 2015*). HydrogeoSieve XL compares the results of the grain size analyses against fifteen (15) different analytical methods.

Given our experience in the area as well as published literature, some of the geometric means provided for the soil were biased low by one or more methods. In these instances, the values determined by these methods were excluded from the mean. The table below illustrates the hydraulic conductivity values estimated from the mean of the analytical methods where the soil met the applicable analysis criteria.

Sample ID	Soil Description	Applicable Analysis Methods	Hydraulic Conductivity (m/s)
BH103-SS4	Clayey Silt Till	Alyamani and Sen, Barr, Sauerbrei	4.2×10^{-9}

The results of the analyses are presented in Appendix D.

6.3 Literature

According to Freeze and Cherry (1979), the typical hydraulic conductivity of the strata investigated at the site are:

Stratum/Formation	Hydraulic Conductivity (m/s)
Earth Fill	1×10^{-3} to 1×10^{-7}
Clayey Silt Glacial Till	1×10^{-7} to 1×10^{-10}
Weathered Shale Bedrock	1×10^{-6} to 1×10^{-12}
Sound Shale Bedrock	1×10^{-7} to 1×10^{-12}



7 Water Quality

One (1) unfiltered groundwater sample was collected and analyzed by a Canadian laboratory accredited and licensed by Standards Council of Canada and or Canadian Association for Laboratory Accreditation.

The sample was collected directly from monitoring well BH101 on May 10, 2021. The sample was analyzed for the following parameters:

- City of Mississauga Storm Sewer By-Law 259-05 – Limits for Storm Sewers Discharge
- Region of Peel By-Law 53-2010 Table 1 – Limits for Sanitary Sewer Discharge

The groundwater sample exceeded the Limits for Storm Sewer Discharge for the following parameters:

- Total Suspended Solids (Limit 15 mg/L, Result 38.2 mg/L)
- Total Kjeldahl Nitrogen (Limit 1 mg/L, Result 1.83 mg/L)
- E. Coli (Limit 200 CFU/100mL, Result 270 CFU/100mL)
- Phosphorus (Limit 0.4 mg/L, Result <0.50 mg/L)

The groundwater sample met the Limits for Sanitary and Combined Sewer Discharge for all parameters analyzed.

A true copy of the analysis report, Certificate of Analysis and a chain of custody record for the sample are enclosed.

8 Proposed Construction Method

The proposed shoring methodology at the site is currently undetermined. For the purposes of this report, numerical analyses were conducted employing conventional soldier piling and lagging in order to determine a “worst-case scenario” with respect to dewatering volumes and groundwater seepage at the site.

For design purposes, the stabilized groundwater table is at about Elev. 107.7± m. The water table is present in the clayey silt till soil units. The lowest (P5) FFE is at about Elev. 94 m. Therefore,

- Bulk excavation will extend down to the elevation of the prevailing groundwater table;
- Foundation excavations will extend below the prevailing groundwater table; and
- Foundation excavations will penetrate sound bedrock yielding minor seepage.

The groundwater table is in the clayey silt till deposits and bedrock. Dewatering will take some time to accomplish prior to the start of excavation. Stored water within the excavation will need to be considered prior to excavation/dewatering. The clayey silt till deposit has a very low permeability and will yield minor seepage. Positive dewatering of soils may not be feasible at this site due to permeability of the soils present. Dewatering may be achieved through conventional sump pump arrangements. Dewatering of the bedrock is not required, seepage can be allowed to



drain into the excavation and pumped accordingly. Failure to dewater prior to excavation may result in unrecoverable disturbance of the subgrade, which will render advice provided for undisturbed subgrade conditions inapplicable.

It is recommended that a professional dewatering contractor be consulted to review the subsurface conditions and to design a site-specific dewatering system. It is the dewatering contractor's responsibility to assess the factual data and to provide recommendations on dewatering system requirements.

The proposed structures will consist of drained foundations.

The City of Mississauga and/or the Region of Peel will require Discharge Agreements in the short and long terms, if any water is to be discharged to the storm or sanitary sewers. It should be noted that securing a permit to take water on a permanent basis may not be supported by regulatory agencies.

9 Private Water Drainage System (PWDS)

If the proposed development consists of drained foundations, then a private water drainage system will be required. The total sub floor drain area will be approximately 9,685 m² based on the drawings which have been provided.

If the development is designed with a private water drainage system, the drainage system is a critical structural element since it keeps water pressure from acting on the basement walls and floor slab. As such, the sump that ensures the performance of this system must have a duplexed pump arrangement for 100% pumping redundancy and these pumps must be on emergency power. The size of the sump should be adequate to accommodate the estimated groundwater seepage. It is anticipated that the groundwater seepage can be controlled with typical, widely available, commercial/residential sump pumps.

If the proposed development is designed as a leak tight structure, then a private water drainage system will not be required. However, the structure must then be designed to resist hydrostatic pressure and uplift forces.

10 Groundwater Extraction and Discharge

Numerical analyses were conducted for both short term and long term dewatering scenarios. The modeling was conducted using computer software, which deploys the finite element modelling method. The Finite Element Model (FEM) for groundwater seepage indicates the short term (construction) and long term (permanent) dewatering requirements as provided below. The finite element model results are presented in Appendix E.

The groundwater seepage estimates, which have been provided, represent the steady state groundwater seepage. There will be an initial drawdown of the groundwater before a steady state



condition is reached. The rate of the initial drawdown, and therefore discharge, is dependent on the dewatering contractor and how the groundwater is being dealt with at the site. An estimated initial volume of stored groundwater which will require removal before steady state is reached has been provided below.

Please note that if excavation is exposed to the elements, storm water will have to be managed. The short term control of groundwater should consider stormwater management from rainfall events. A dewatering system should be designed to consider the removal of rainfall from excavation. A design storm of 25 mm has been used in the quantity estimates.

As required by Ontario Regulation 63/16, a plan for discharge must consider the conveyance of storm water from a 100-year storm. The additional volume that will be generated in the occurrence of a 100-year storm event is approximately 916,000 L.

Stored Groundwater (pre-excavation/dewatering)					
Volume of Excavation (m³)	Volume of Excavation Below Water Table (m³)	Volume of Stored Groundwater		Volume of Available Groundwater	
		(m³)	(L)	(m³)	(L)
180,264	148,109	13,300	13,300,000	8,700	8,700,000

Short Term (Construction) Groundwater Quantity – Safety Factor of 2.0 Used					
Groundwater Seepage		Design Rainfall Event (25mm)		Total Daily Water Takings	
L/day	L/min	L/day	L/min	L/day	L/min
10,000	6.9	244,000	169.4	254,000	176.4

Long Term (Permanent) Groundwater Quantity – Safety Factor of 2.0 Used					
Groundwater Seepage		Infiltration Design Rainfall Event (25mm)		Total Daily Water Takings	
L/day	L/min	L/day	L/min	L/day	L/min
10,000	6.9	21,000	14.6	31,000	21.5

Regulatory Requirements	
Environmental Activity and Sector Registry (EASR) Posting	Required
Short Term Permit to Take Water (PTTW)	Not Required



Regulatory Requirements

Long Term Permit to Take Water (PTTW)	Not Required
Short Term Discharge Agreement City of Mississauga/Region of Peel	Required
Long Term Discharge Agreement City of Mississauga/Region of Peel	Required

Please note:

- The proposed pump schedule for short term construction dewatering has not been completed. As such, the actual peak short term discharge rate is not available at the time of writing this report. The pump schedule must be specified by either the dewatering contractor retained or the mechanical consultant.
- The proposed pump schedule for long term permanent drainage has not been completed. As such the actual peak long term discharge rate is not available at the time writing of this report. The pump schedule must be specified by the mechanical consultant.
- A leak-tight structure (structure that has not included a private water drainage system) has not been considered as part of the proposed development at this time.
- On-site containment (infiltration gallery/dry well etc.) has not been considered as part of the proposed development at this time. If this option is considered, additional work will have to be conducted (i.e. infiltration testing).

11 Evaluation of Impact

11.1 Zone of Influence (ZOI)

The Zone of Influence (ZOI) with respect to groundwater was calculated based on the estimated groundwater taking rate and the hydraulic conductivity of the unit which water will be taken at the Property.

The ZOI was calculated using the Sichardt equation below.

Equation: $R_0 = 3000 * dH * K^{0.5}$

Where:

dH is the dewatering thickness (m)

K is the hydraulic conductivity (m/s)

Calculation:



Geological Unit	dH (m)	K (m/s)	ZOI (m)
Fill	1.7	1.0×10^{-5}	16
Clayey Silt Glacial Till	2.1	4.1×10^{-8}	1

The ZOI with respect to groundwater seepage at the site is 17 m.

11.2 Land Stability

The impacts to land stability of the proposed short term and long term dewatering at the site on adjacent structures are summarized as follows:

- The proposed dewatering at the subject site locally lowers the groundwater table within the ZOI by a maximum of 3.8 m. This drawdown would create an increase in effective stress of approximately 38 kPa in the native soils.
- Based on the change in effective stress and the compressibility of the soil subjected to that change, the proposed dewatering activities will induce a theoretical maximum 8 mm of additional settlement in the adjacent soils.
- The maximum induced settlement occurs directly adjacent to the proposed excavation and decreases in a nonlinear fashion with distance away from the excavation.
- For the structures within the public realm adjacent to the site, the theoretical dewatering-induced settlement is calculated to be 3 mm or less (depending on the depth of the structure).

On this basis, the impact of the proposed dewatering on the existing adjacent structures is considered by Grounded to be within acceptable limits.

11.3 City's Sewage Works

Negative impacts to City's sewage works may occur in terms of the quantity or quality of the groundwater discharged. This report provided the estimated quantity of the water discharge. However, this report does not speak to the sewer capacities. The sewer capacity analysis is provided under a separate cover by the civil consultant.

The quality of the proposed groundwater discharge is provided in Section 7. As noted in that section, the groundwater sample exceeded the Limits for Storm Sewer Discharge and met the Limits for Sanitary and Combined Sewer Discharge.

As such additional treatment will be required before the water can be discharged to the Storm Sewer and additional treatment will not be required before the water can be discharged to the Sanitary and Combined Sewer, to avoid impacts to the City's sewage works caused by groundwater quality.



11.4 Natural Environment

Cooksville Creek is located adjacent to east boundary of site but is hydraulically cut off from the site by a concrete retaining wall that appears to be bearing on bedrock. Therefore, the creek will likely not be affected by the proposed construction and long term dewatering. There are no other natural waterbodies within the ZOI that will be affected by the proposed construction dewatering or permanent drainage. Any groundwater which will be taken from the site will be discharged (if required) into the City's sewer systems and not into any natural water body. As such, there will be no impact to the natural environment caused by the water takings at the site.

11.5 Local Drinking Water Wells

The site is located within the municipal boundaries of the City of Mississauga. The site and surrounding area are provided with municipal piped water and sewer supply. There is no use of the groundwater for water supply in this area of Mississauga. As such, there will be no impact to drinking water wells.

11.6 Contamination Source

The site and immediately surrounding area currently consist mostly of residential and commercial areas. These land uses are anticipated to be a source of potential contamination and are expected to provide an Area of Potential Environmental Concern for the site. As such, the pumping of groundwater at the site is anticipated to facilitate the movement of potential contaminants onto the site. Evaluation of the environmental condition of the site has been completed under a separate cover.

12 Proposed Mitigation Measures and Monitoring Plan

The extent of the negative impact identified in previous sections will be limited to the ZOI caused by the groundwater taking at the site.

As a result of dewatering and draining the soil, changes in groundwater level have the potential to cause settlement based on the change in the effective stresses within the ZOI.

If adjacent buildings or municipal infrastructure are within the ZOI and will undergo settlement that may be considered unacceptable as identified the Land Stability Section, consideration should be given to implement a monitoring and mitigation program during dewatering activities.

Both the temporary construction dewatering system and the permanent building drainage system must be properly installed and screened to ensure sediments and fines will not be removed, which is typically a primary cause of dewatering related settlement.



13 Limitations

Natural occurrences, the passage of time, local construction, and other human activity all have the potential to directly or indirectly alter the subsurface conditions at or near the project site. Contractual obligations related to groundwater or stormwater control must be considered with attention and care as they relate this potential site alteration.

The hydrogeological engineering advice provided in this report is based on the factual observations made from the site investigations as reported. It is intended for use by the owner and their retained design team. If there are changes to the features of the development or to the scope, the interpreted subsurface information, geotechnical engineering design parameters, advice, and discussion on construction considerations may not be relevant or complete for the project. Grounded should be retained to review the implications of such changes with respect to the contents of this report.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Grounded accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report, including consequential financial effects on transactions or property values, or requirements for follow-up actions and costs.

13.1 Report Use

The authorized users of this report are ACLP - Dundas Street E and their design team, for whom this report has been prepared. Grounded Engineering Inc. maintains the copyright and ownership of this document. Reproduction of this report in any format or medium requires explicit prior authorization from Grounded Engineering Inc. The City of Mississauga may also make use of and rely upon this report, subject to the limitations as stated.

14 Closure

If there are any questions regarding the discussion and advice provided, please do not hesitate to contact our office. We trust that this report meets your requirements at present.

For and on behalf of our team,



Nico Piers, BAsC, EIT



Matthew Bielaski, P.Eng., QP_{RA-ESA}
Principal

FIGURES





GROUNDED
ENGINEERING

1 BANIGAN DRIVE, TORONTO, ONT., M4H 1G3
www.grounedeng.ca

LEGEND

— APROXIMATE PROPERTY BOUNDARY

Note

Reference

ArcGIS Map 2021


Project

60 DUNDAS STREET EAST, MISSISSAUGA, ON

Figure Title

SITE LOCATION PLAN

North



Date

FEBRUARY 2022

Scale

AS INDICATED

Job No

21-067


Figure No

FIGURE 1

DUNDAS STREET EAST

PIN 13157-0083 (LT)

SHEPARD AVENUE



GROUND
ENGINEERING

1 BANIGAN DRIVE, TORONTO, ONT., M4H 1G3
www.groundedeng.ca

LEGEND

- APPROXIMATE PROPERTY BOUNDARY
- EXISTING BUILDING STRUCTURE
- MONITORING WELL BY GROUND
- CATCHBASIN
- MAINTENANCE HOLE

Note

Reference


Survey Drawing no. 20-21-14108-00.
Prepared by Aksan Piller Corporation Ltd.
Dated April 5, 2021.

Project

60 DUNDAS STREET EAST, MISSISSAUGA, ON

Figure Title
BOREHOLE AND MONITORING WELL LOCATION PLAN

North



Date

FEBRUARY 2022

Scale

AS INDICATED

Job No

21-067

Figure No

FIGURE 2

LEGEND

- FILL
- GRAVELS (gravel to gravelly sand)
- SILT TO SAND (not till)
- COHESIONLESS TILLS
- COHESIVE SOILS (clayey silt to clay, incl. tills)
- DISTURBED/REWORKED SOILS

- water level, unstabilized
- water level, stabilized

Project
**60 DUNDAS STREET EAST
MISSISSAUGA, ON**



Figure Title
**SUBSURFACE
CROSS-SECTION
NE-SW**

Date
FEBRUARY 2022

Scale
AS INDICATED

Job No
21-067

Figure No
FIGURE 3



LITHOLOGY GRAPHIC LEGEND

- Asphalt
- Bedrock (inferred)
- Aggregate
- Topsoil
- Fill
- Clayey Silt Till

APPENDIX A



SAMPLING/TESTING METHODS

SS: split spoon sample
 AS: auger sample
 GS: grab sample
 FV: shear vane
 DP: direct push
 PMT: pressuremeter test
 ST: shelby tube
 CORE: soil coring
 RUN: rock coring

SYMBOLS & ABBREVIATIONS

MC: moisture content
 LL: liquid limit
 PL: plastic limit
 NP: non-plastic
 γ : soil unit weight (bulk)
 G_s : specific gravity
 S_u : undrained shear strength
 unstabalized water level
 1st water level measurement
 2nd water level measurement most recent
 water level measurement

ENVIRONMENTAL SAMPLES

M&I: metals and inorganic parameters
 PAH: polycyclic aromatic hydrocarbon
 PCB: polychlorinated biphenyl
 VOC: volatile organic compound
 PHC: petroleum hydrocarbon
 BTEX: benzene, toluene, ethylbenzene and xylene
 PPM: parts per million

FIELD MOISTURE (based on tactile inspection)

DRY: no observable pore water
MOIST: inferred pore water, not observable (i.e. grey, cool, etc.)
WET: visible pore water

COHESIONLESS

Relative Density	N-Value
Very Loose	<4
Loose	4 - 10
Compact	10 - 30
Dense	30 - 50
Very Dense	>50

COHESIVE

Consistency	N-Value	Su (kPa)
Very Soft	<2	<12
Soft	2 - 4	12 - 25
Firm	4 - 8	25 - 50
Stiff	8 - 15	50 - 100
Very Stiff	15 - 30	100 - 200
Hard	>30	>200

COMPOSITION

Term	% by weight
trace silt	<10
some silt	10 - 20
silty	20 - 35
sand and silt	>35

ASTM STANDARDS

ASTM D1586 Standard Penetration Test (SPT)

Driving a 51 mm O.D. split-barrel sampler ("split spoon") into soil with a 63.5 kg weight free falling 760 mm. The blows required to drive the split spoon 300 mm ("bpf") after an initial penetration of 150 mm is referred to as the N-Value.

ASTM D3441 Cone Penetration Test (CPT)

Pushing an internal still rod with a outer hollow rod ("sleeve") tipped with a cone with an apex angle of 60° and a cross-sectional area of 1000 mm² into soil. The resistance is measured in the sleeve and at the tip to determine the skin friction and the tip resistance.

ASTM D2573 Field Vane Test (FVT)

Pushing a four blade vane into soil and rotating it from the surface to determine the torque required to shear a cylindrical surface with the vane. The torque is converted to the shear strength of the soil using a limit equilibrium analysis.


ASTM D1587 Shelby Tubes (ST)

Pushing a thin-walled metal tube into the in-situ soil at the bottom of a borehole, removing the tube and sealing the ends to prevent soil movement or changes in moisture content for the purposes of extracting a relatively undisturbed sample.

ASTM D4719 Pressuremeter Test (PMT)

Place an inflatable cylindrical probe into a pre-drilled hole and expanding it while measuring the change in volume and pressure in the probe. It is inflated under either equal pressure increments or equal volume increments. This provides the stress-strain response of the soil.


WELL LEGEND



File No. : 21-067

Project : 60 Dundas Street East, Mississauga, ON

Client : Almega Asset Management



END OF BOREHOLE

Dry and open upon completion of drilling.
50 mm dia. monitoring well installed.
No. 10 screen


GROUNDWATER LEVELS

Date	Water Depth (m)	Elevation (m)
May 4, 2021	4.7	106.2
May 6, 2021	3.5	107.4
May 10, 2021	3.3	107.6

File No. : 21-067

Project : 60 Dundas Street East, Mississauga, ON

Client : Almega Asset Management



END OF BOREHOLE
Auger refusal on inferred bedrock

Dry and open upon completion of drilling.


50 mm dia. monitoring well installed.
No. 10 screen

GROUNDWATER LEVELS		
Date	Water Depth (m)	Elevation (m)
May 4, 2021	4.7	105.3
May 6, 2021	4.0	106.0
May 10, 2021	3.8	106.2

File No. : 21-067

Project : 60 Dundas Street East, Mississauga, ON

Client : Almega Asset Management



END OF BOREHOLE
Auger refusal on inferred bedrock

Dry and open upon completion of drilling.

50 mm dia. monitoring well installed.
No. 10 screen

GROUNDWATER LEVELS

Date	Water Depth (m)	Elevation (m)
May 4, 2021	4.6	104.8
May 6, 2021	4.1	105.3
May 10, 2021	4.1	105.3

APPENDIX B






Slug Test Analysis Report

Project: 60 Dundas St E, Mississauga

Number: 21-067

Client:

Location:	Slug Test: BH101	Test Well: BH101
Test Conducted by: OM		Test Date: 2021-05-10
Analysis Performed by: DK	RHT-BH101	Analysis Date: 2021-05-13
Aquifer Thickness: 6.30 m		



Calculation using Bouwer & Rice		
Observation Well	Hydraulic Conductivity [m/s]	
BH101	6.78×10^{-8}	




Slug Test Analysis Report

Project: 60 Dundas St E, Mississauga

Number: 21-067

Client:

Location:	Slug Test: BH102	Test Well: BH102
Test Conducted by: OM		Test Date: 2021-05-10
Analysis Performed by: DK	RHT-BH102	Analysis Date: 2021-05-13
Aquifer Thickness: 6.30 m		



Calculation using Bouwer & Rice

Observation Well	Hydraulic Conductivity [m/s]
BH102	1.65×10^{-8}




Slug Test Analysis Report

Project: 60 Dundas St E, Mississauga

Number: 21-067

Client:

Location:	Slug Test: BH103	Test Well: BH103
Test Conducted by: OM		Test Date: 2021-05-11
Analysis Performed by: DK	RHT-BH103	Analysis Date: 2021-05-13
Aquifer Thickness: 6.30 m		



Calculation using Bouwer & Rice

Observation Well	Hydraulic Conductivity [m/s]	
BH103	6.23×10^{-8}	

APPENDIX C



ATTERBERG LIMITS - LIQUID AND PLASTIC

LABORATORY NO.:	2102782 B	PROJECT NO.:	21TM720	DATE:	May 18, 2021
BOREHOLE NO.:	103	SAMPLE NO.:	SS4	TESTED BY:	L. Gowry
SAMPLE DEPTH:	7.5-9 ft	DESCRIPTION:		CHECKED BY:	J. Noor


LIQUID LIMIT					
TRIAL	1	2	3	4	5
NUMBER OF BLOWS	30	20	15		
TARE NUMBER	H1	P4	N4		
WT. TARE & WET SOIL	43.42	42.92	39.09		
WT. TARE & DRY SOIL	38.79	38.21	35.09		
WT. OF WATER	4.63	4.71	4.00		
WT. OF TARE	19.96	19.98	20.14		
WT. OF DRY SAMPLE	18.83	18.23	14.95		
MOISTURE CONTENT	24.6	25.8	26.8		

ATTERBERG LIMITS		PLASTIC LIMIT		
LIQUID LIMIT	25	TRIAL	1	2
PLASTIC LIMIT	16	TARE NUMBER	P10	x23
PLASTICITY INDEX	9	WT. TARE & WET SOIL	27.75	27.57
		WT. TARE & DRY SOIL	26.65	26.53
		WT. OF WATER	1.10	1.04
		WT. OF TARE	19.83	20.03
		WT. OF DRY SAMPLE	6.82	6.50
		MOISTURE CONTENT	16.1	16.0


LIQUID LIMIT BEST-LINE CALCULATION & ASSESSMENT						
LOG OF BLOWS	MOISTURE CONTENTS		ERROR EVALUATION			
			BLOW COUNT	MOISTURE CONTENT	DIFFERENCE	WITHIN 1%?
1.4771213	24.6		30	24.6	0.0	TRUE
1.30103	25.8		20	25.8	0.0	TRUE
1.1760913	26.8		15	26.7	0.0	TRUE
SLOPE	INTERCEPT					
-7.19268	35.20747		ERROR ASSESSMENT			PASSES

ATTERBERG LIMITS - LIQUID AND PLASTIC

LABORATORY NO.:	2102782 B	PROJECT NO.:	21TM720	DATE:	May 18, 2021
BOREHOLE NO.:	103	SAMPLE NO.:	SS4	TESTED BY:	L. Gowry
SAMPLE DEPTH:	7.5-9 ft	DESCRIPTION:		CHECKED BY:	J. Noor



PARTICLE SIZE DISTRIBUTION CHART



SILT & CLAY				FINE SAND			COARSE SAND	GRAVEL		COBBLES	UNIFIED
CLAY	FINE SILT	MEDIUM SILT	COARSE SILT	FINE SAND	MEDIUM SAND	COARSE SAND	GRAVEL		COBBLES	M.I.T.	
CLAY	SILT			VERY FINE SAND	FINE SAND	MEDIUM SAND	COARSE SAND	GRAVEL		U.S. BUREAU	

REMARKS Bore Hole 103, Sample No.SS4, Depth 7.5-9, Lab No.2102782-B,

APPENDIX D





K from Grain Size Analysis Report

Date: 20-May-21

Sample Name:

BH103 SS4


Mass Sample (g):

100

T (oC)

20

Poorly sorted clay with fines



Estimation of Hydraulic Conductivity	cm/s	m/s	m/d	de
Hazen	3.0E-07	3.0E-09	0.00	
Hazen K (cm/s) = d ₁₀ (mm)	5.3E-07	5.3E-09	0.00	
Slichter	5.9E-08	5.9E-10	0.00	
Terzaghi	8.4E-08	8.4E-10	0.00	
Beyer	2.7E-07	2.7E-09	0.00	
Sauerbrei	1.8E-07	1.8E-09	0.00	
Kruger	3.0E-05	3.0E-07	0.03	
Kozeny-Carmen	6.1E-06	6.1E-08	0.01	
Zunker	4.7E-06	4.7E-08	0.00	
Zamarrin	5.5E-06	5.5E-08	0.00	
USBR	2.2E-07	2.2E-09	0.00	
Barr	6.4E-08	6.4E-10	0.00	
Alyamani and Sen	6.4E-06	6.4E-08	0.01	
Chapuis	9.1E-10	9.1E-12	0.00	
Krumbein and Monk	1.6E-05	1.6E-07	0.01	
geometric mean	4.2E-07	4.2E-09	0.00	
arithmetic mean	2.2E-06	2.2E-08	0.00	

APPENDIX E





Grounded Engineering Inc
ATTN: DEEPAK KANRAJ
12 Banigan Drive
Toronto On M4H1E9

Date Received: 10-MAY-21
Report Date: 19-MAY-21 09:46 (MT)
Version: FINAL

Client Phone: 647-264-7928

Certificate of Analysis

Lab Work Order #: L2585834
Project P.O. #: NOT SUBMITTED
Job Reference: 21-067
C of C Numbers:
Legal Site Desc:

Jennifer Barkshire-Paterson
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 5730 Coopers Avenue, Unit #26, Mississauga, ON L4Z 2E9 Canada | Phone: +1 905 507 6910 | Fax: +1 905 507 6927
ALS CANADA LTD Part of the ALS Group An ALS Limited Company

Summary of Guideline Exceedances

Guideline		Grouping	Analyte	Result	Guideline Limit	Unit
ALS ID	Client ID					
Ontario Sewer Use Bylaws - Peel Sanitary Sewer (53-2010)						
(No parameter exceedances)						
Ontario Sewer Use Bylaws - Mississauga Storm Sewer (259-05)						
L2585834-1	SEW- UF- BH 101	Physical Tests	Total Suspended Solids	38.2	15	mg/L
		Anions and Nutrients	Total Kjeldahl Nitrogen	1.83	1	mg/L
		Bacteriological Tests	E. Coli	270	200	CFU/100mL
		Total Metals	Phosphorus (P)-Total	<0.50	0.4	mg/L

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Physical Tests - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
pH	pH units	5.5-10	6-9	8.15
Total Suspended Solids	mg/L	350	15	38.2

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

- Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.
- Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Anions and Nutrients - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
Fluoride (F)	mg/L	10	-	0.73 ^{DLDS}
Total Kjeldahl Nitrogen	mg/L	100	1	1.83
Phosphorus, Total	mg/L	10	0.4	0.0173
Sulfate (SO4)	mg/L	1500	-	191 ^{DLDS}

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

- Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.
- Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Cyanides - WATER


Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101


Guide Limits
Unit #1 #2

Analyte	Unit	#1	#2	
Cyanide, Total	mg/L	2	0.02	0.0030

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

 Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

 Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

Inorganic Parameters - WATER


Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101


Guide Limits
Unit #1 #2

Analyte	Unit	#1	#2	
Chlorine, Total	mg/L	-	1	<0.050 ^{PEHR}

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

 Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

 Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

Bacteriological Tests - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Guide Limits

Analyte	Unit	Guide Limits		
		#1	#2	
E. Coli	CFU/100m L	-	200	270 ^{DLM}

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

 Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

 Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Total Metals - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
Aluminum (Al)-Total	mg/L	50	1.0	0.564 ^{DLHC}
Antimony (Sb)-Total	mg/L	5	-	0.0016 ^{DLHC}
Arsenic (As)-Total	mg/L	1	0.02	0.0021 ^{DLHC}
Barium (Ba)-Total	mg/L	-	-	0.0670 ^{DLHC}
Beryllium (Be)-Total	mg/L	-	-	<0.0010 ^{DLHC}
Bismuth (Bi)-Total	mg/L	-	-	<0.00050 ^{DLHC}
Boron (B)-Total	mg/L	-	-	1.57 ^{DLHC}
Cadmium (Cd)-Total	mg/L	0.7	0.008	<0.000050 ^{DLHC}
Calcium (Ca)-Total	mg/L	-	-	40.7 ^{DLHC}
Chromium (Cr)-Total	mg/L	5	0.08	<0.0050 ^{DLHC}
Cobalt (Co)-Total	mg/L	5	-	<0.0010 ^{DLHC}
Copper (Cu)-Total	mg/L	3	0.04	<0.0050 ^{DLHC}
Iron (Fe)-Total	mg/L	-	-	0.68 ^{DLHC}
Lead (Pb)-Total	mg/L	3	0.120	<0.00050 ^{DLHC}
Lithium (Li)-Total	mg/L	-	-	0.104 ^{DLHC}
Magnesium (Mg)-Total	mg/L	-	-	9.69 ^{DLHC}
Manganese (Mn)-Total	mg/L	5	0.05	0.0352 ^{DLHC}
Mercury (Hg)-Total	mg/L	0.01	0.0004	<0.0000050 ^{DLHC}
Molybdenum (Mo)-Total	mg/L	5	-	0.0118 ^{DLHC}
Nickel (Ni)-Total	mg/L	3	0.08	<0.0050 ^{DLHC}
Phosphorus (P)-Total	mg/L	10	0.4	<0.50 ^{DLHC}
Potassium (K)-Total	mg/L	-	-	28.1 ^{DLHC}
Selenium (Se)-Total	mg/L	1	0.02	<0.00050 ^{DLHC}
Silicon (Si)-Total	mg/L	-	-	4.0 ^{DLHC}
Silver (Ag)-Total	mg/L	5	0.12	<0.00050 ^{DLHC}
Sodium (Na)-Total	mg/L	-	-	252 ^{DLHC}
Strontium (Sr)-Total	mg/L	-	-	1.77 ^{DLHC}
Sulfur (S)-Total	mg/L	-	-	61.0 ^{DLHC}
Thallium (Tl)-Total	mg/L	-	-	<0.00010 ^{DLHC}
Tin (Sn)-Total	mg/L	5	-	0.0040 ^{DLHC}

Guide Limit #1: Peel Sanitary Sewer (53-2010)
Guide Limit #2: Mississauga Storm Sewer (259-05)

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Total Metals - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
101

Analyte	Unit	Guide Limits		
		#1	#2	
Titanium (Ti)-Total	mg/L	5	-	<0.0060 ^{DLUI}
Tungsten (W)-Total	mg/L	-	-	<0.0010 ^{DLHC}
Uranium (U)-Total	mg/L	-	-	0.00287 ^{DLHC}
Vanadium (V)-Total	mg/L	-	-	<0.0050 ^{DLHC}
Zinc (Zn)-Total	mg/L	3	0.04	<0.030 ^{DLHC}
Zirconium (Zr)-Total	mg/L	-	-	<0.0020 ^{DLHC}

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

- Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.
- Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

Speciated Metals - WATER


Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101


Guide Limits
Unit #1 #2

Analyte	Unit	#1	#2	
Chromium, Hexavalent	mg/L	-	0.04	<0.00050

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

 Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

 Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Aggregate Organics - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
BOD	mg/L	300	15	<3.0 ^{BODL}
BOD Carbonaceous	mg/L	300	-	<3.0 ^{BODL}
Oil and Grease, Total	mg/L	-	-	5.8
Animal/Veg Oil & Grease	mg/L	150	-	5.8
Mineral Oil and Grease	mg/L	15	-	<2.5
Phenols (4AAP)	mg/L	1	0.008	0.0024

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

- Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.
- Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Volatile Organic Compounds - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
Acetone	ug/L	-	-	<20
Benzene	ug/L	10	2	<0.50
Bromodichloromethane	ug/L	-	-	<1.0
Bromoform	ug/L	-	-	<1.0
Bromomethane	ug/L	-	-	<0.50
Carbon Disulfide	ug/L	-	-	<1.0
Carbon tetrachloride	ug/L	-	-	<0.20
Chlorobenzene	ug/L	-	-	<0.50
Dibromochloromethane	ug/L	-	-	<1.0
Chloroethane	ug/L	-	-	<1.0
Chloroform	ug/L	40	-	<1.0
Chloromethane	ug/L	-	-	<1.0
1,2-Dibromoethane	ug/L	-	-	<0.20
1,2-Dichlorobenzene	ug/L	50	-	<0.50
1,3-Dichlorobenzene	ug/L	-	-	<0.50
1,4-Dichlorobenzene	ug/L	80	-	<0.50
Dichlorodifluoromethane	ug/L	-	-	<1.0
1,1-Dichloroethane	ug/L	-	-	<0.50
1,2-Dichloroethane	ug/L	-	-	<0.50
1,1-Dichloroethylene	ug/L	-	-	<0.50
cis-1,2-Dichloroethylene	ug/L	4000	-	<0.50
trans-1,2-Dichloroethylene	ug/L	-	-	<0.50
Dichloromethane	ug/L	2000	-	<2.0
1,2-Dichloropropane	ug/L	-	-	<0.50
cis-1,3-Dichloropropene	ug/L	-	-	<0.30
trans-1,3-Dichloropropene	ug/L	140	-	<0.30
Ethylbenzene	ug/L	160	2	<0.50
n-Hexane	ug/L	-	-	<0.50
2-Hexanone	ug/L	-	-	<20
Methyl Ethyl Ketone	ug/L	8000	-	<20

Guide Limit #1: Peel Sanitary Sewer (53-2010)
Guide Limit #2: Mississauga Storm Sewer (259-05)

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Volatile Organic Compounds - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
Methyl Isobutyl Ketone	ug/L	-	-	<20
MTBE	ug/L	-	-	<0.50
Styrene	ug/L	200	-	<0.50
1,1,1,2-Tetrachloroethane	ug/L	-	-	<0.50
1,1,2,2-Tetrachloroethane	ug/L	1400	-	<0.50
Tetrachloroethylene	ug/L	1000	-	<0.50
Toluene	ug/L	270	2	<0.40
				<0.50
1,1,1-Trichloroethane	ug/L	-	-	<0.50
1,1,2-Trichloroethane	ug/L	-	-	<0.50
Trichloroethylene	ug/L	400	-	<0.50
Trichlorofluoromethane	ug/L	-	-	<1.0
Vinyl chloride	ug/L	-	-	<0.50
o-Xylene	ug/L	-	-	<0.50
				<0.30
m+p-Xylenes	ug/L	-	-	<1.0
				<0.40
Xylenes (Total)	ug/L	1400	4.4	<0.50
Surrogate: 4-Bromofluorobenzene	%	-	-	100.9
Surrogate: 1,4-Difluorobenzene	%	-	-	99.7

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

- Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.
- Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Polycyclic Aromatic Hydrocarbons - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
Acenaphthene	ug/L	-	-	<0.020
Acenaphthylene	ug/L	-	-	<0.020
Anthracene	ug/L	-	-	<0.020
Benzo(a)anthracene	ug/L	-	-	<0.020
Benzo(a)pyrene	ug/L	-	-	<0.0050
Benzo(b&j)fluoranthene	ug/L	-	-	<0.020
Benzo(g,h,i)perylene	ug/L	-	-	<0.020
Benzo(k)fluoranthene	ug/L	-	-	<0.020
Chrysene	ug/L	-	-	<0.020
Dibenz(a,h)anthracene	ug/L	-	-	<0.020
Fluoranthene	ug/L	-	-	<0.020
Fluorene	ug/L	-	-	<0.020
Indeno(1,2,3-cd)pyrene	ug/L	-	-	<0.020
Naphthalene	ug/L	-	-	<0.020
Phenanthrene	ug/L	-	-	<0.020
Pyrene	ug/L	-	-	<0.020
Surrogate: Naphthalene d8	%	-	-	95.4
Surrogate: Phenanthrene d10	%	-	-	101.8
Total PAHs	ug/L	-	2	<0.078

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

- Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.
- Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.


Phthalate Esters - WATER


Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
101

Analyte	Unit	Guide Limits		
		#1	#2	
Bis(2-ethylhexyl)phthalate	ug/L	12	-	<2.0
Surrogate: 2-fluorobiphenyl	%	-	-	82.8
Surrogate: p-Terphenyl d14	%	-	-	84.9

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

 Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

 Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.


Semi-Volatile Organics - WATER


Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
Di-n-butylphthalate	ug/L	80	-	<1.0
Surrogate: 2-Fluorobiphenyl	%	-	-	82.8
Surrogate: p-Terphenyl d14	%	-	-	84.9

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

 Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

 Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Polychlorinated Biphenyls - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
Aroclor 1242	ug/L	-	-	<0.020
Aroclor 1248	ug/L	-	-	<0.020
Aroclor 1254	ug/L	-	-	<0.020
Aroclor 1260	ug/L	-	-	<0.020
Surrogate: Decachlorobiphenyl	%	-	-	87.5
Total PCBs	ug/L	1	-	<0.040
Surrogate: Tetrachloro-m-xylene	%	-	-	95.8

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Organic Parameters - WATER

Lab ID L2585834-1
Sample Date 10-MAY-21
Sample ID SEW- UF- BH
 101

Analyte	Unit	Guide Limits		
		#1	#2	
Bisphenol A	ug/L	-	-	<0.20
Nonylphenol	ug/L	20	-	<1.0
Nonylphenol Diethoxylates	ug/L	-	-	<0.10
Total Nonylphenol Ethoxylates	ug/L	200	-	<10
Nonylphenol Monoethoxylates	ug/L	-	-	<10 ^{DLM}
Octylphenol	ug/L	-	-	<1.0
Octylphenol Diethoxylates	ug/L	-	-	<0.50 ^{DLM}
Total Octylphenol Ethoxylates	ug/L	-	-	<10
Octylphenol Monoethoxylates	ug/L	-	-	<10 ^{DLM}

Guide Limit #1: Peel Sanitary Sewer (53-2010)

Guide Limit #2: Mississauga Storm Sewer (259-05)

Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

Analytical result for this parameter exceeds Guide Limits listed. See Summary of Guideline Exceedances.

* Please refer to the Reference Information section for an explanation of any qualifiers noted.

Reference Information

Qualifiers for Individual Parameters Listed:

Qualifier	Description
DLDS	Detection Limit Raised: Dilution required due to high Dissolved Solids / Electrical Conductivity.
PEHR	Parameter Exceeded Recommended Holding Time On Receipt: Proceed With Analysis As Requested.
DLUI	Detection Limit Raised: Unknown Interference generated an apparent false positive test result.
BODL	Limit of Reporting for BOD was increased to account for the largest volume of sample tested.
DLM	Detection Limit Adjusted due to sample matrix effects (e.g. chemical interference, colour, turbidity).
DLHC	Detection Limit Raised: Dilution required due to high concentration of test analyte(s).

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Method Reference**
625-BIS-2-PHTH-WT	Water	Bis(2-ethylhexyl)phthalate	SW846 8270
Aqueous samples are extracted and extracts are analyzed on GC/MSD.			
625-DNB-PHTH-WT	Water	Di-n-Butyl Phthalate	SW846 8270
Aqueous samples are extracted and extracts are analyzed on GC/MSD.			
BOD-C-WT	Water	BOD Carbonaceous	APHA 5210 B (CBOD)
This analysis is carried out using procedures adapted from APHA Method 5210B - "Biochemical Oxygen Demand (BOD)". All forms of biochemical oxygen demand (BOD) are determined by diluting and incubating a sample for a specified time period, and measuring the oxygen depletion using a dissolved oxygen meter. Dissolved BOD (SOLUBLE) is determined by filtering the sample through a glass fibre filter prior to dilution. Carbonaceous BOD (CBOD) is determined by adding a nitrification inhibitor to the diluted sample prior to incubation.			
BOD-WT	Water	BOD	APHA 5210 B
This analysis is carried out using procedures adapted from APHA Method 5210B - "Biochemical Oxygen Demand (BOD)". All forms of biochemical oxygen demand (BOD) are determined by diluting and incubating a sample for a specified time period, and measuring the oxygen depletion using a dissolved oxygen meter. Dissolved BOD (SOLUBLE) is determined by filtering the sample through a glass fibre filter prior to dilution. Carbonaceous BOD (CBOD) is determined by adding a nitrification inhibitor to the diluted sample prior to incubation.			
BTX-HS-WT	Water	BTEX by Headspace	SW846 8260 (HEADSPACE)
BTX is determined by analyzing by headspace-GC/MS.			
CL2-TOTAL-WT	Water	Total Residual Chlorine	APHA 4500-CL G
Chlorine (residual), as free or total, is analyzed using the DPD colourimetric method. The recommended hold time for these tests is 15 minutes; field testing is recommended for best results. Chlorine can be rapidly consumed by organic matter, if present, and dissipates rapidly into headspace.			
CN-TOT-WT	Water	Cyanide, Total	ISO 14403-2
Total cyanide is determined by the combination of UV digestion and distillation. Cyanide is converted to cyanogen chloride by reacting with chloramine-T, the cyanogen chloride then reacts with a combination of barbituric acid and isonicotinic acid to form a highly colored complex.			
When using this method, high levels of thiocyanate in samples can cause false positives at ~1-2% of the thiocyanate concentration. For samples with detectable cyanide analyzed by this method, ALS recommends analysis for thiocyanate to check for this potential interference			
CR-CR6-IC-WT	Water	Chromium +6	EPA 7199
This analysis is carried out using procedures adapted from "Test Methods for Evaluating Solid Waste" SW-846, Method 7199, published by the United States Environmental Protection Agency (EPA). The procedure involves analysis for chromium (VI) by ion chromatography using diphenylcarbazide in a sulphuric acid solution. Chromium (III) is calculated as the difference between the total chromium and the chromium (VI) results.			

Reference Information

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Method Reference**
<p>Analysis conducted in accordance with the Protocol for Analytical Methods Used in the Assessment of Properties under Part XV.1 of the Environmental Protection Act (July 1, 2011).</p>			
EC-SCREEN-WT	Water	Conductivity Screen (Internal Use Only)	APHA 2510
<p>Qualitative analysis of conductivity where required during preparation of other tests - e.g. TDS, metals, etc.</p>			
EC-WW-MF-WT	Water	E. Coli	SM 9222D
<p>A 100 mL volume of sample is filtered through a membrane, the membrane is placed on mFC-BCIG agar and incubated at 44.5 – 0.2 °C for 24 – 2 h. Method ID: WT-TM-1200</p>			
F-IC-N-WT	Water	Fluoride in Water by IC	EPA 300.1 (mod)
<p>Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.</p>			
HG-T-CVAA-WT	Water	Total Mercury in Water by CVAAS	EPA 1631E (mod)
<p>Water samples undergo a cold-oxidation using bromine monochloride prior to reduction with stannous chloride, and analyzed by CVAAS.</p>			
MET-T-CCMS-WT	Water	Total Metals in Water by CRC ICPMS	EPA 200.2/6020A (mod)
<p>Water samples are digested with nitric and hydrochloric acids, and analyzed by CRC ICPMS.</p>			
<p>Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered by this method.</p>			
<p>Analysis conducted in accordance with the Protocol for Analytical Methods Used in the Assessment of Properties under Part XV.1 of the Environmental Protection Act (July 1, 2011).</p>			
NP,NPE-LCMS-WT	Water	Nonylphenols and Ethoxylates by LC/MS-MS	J. Chrom A849 (1999) p.467-482
<p>Water samples are filtered and analyzed on LCMS/MS by direct injection.</p>			
OGG-SPEC-CALC-WT	Water	Speciated Oil and Grease A/V Calc	CALCULATION
<p>Sample is extracted with hexane, sample speciation into mineral and animal/vegetable fractions is achieved via silica gel separation and is then determined gravimetrically.</p>			
OGG-SPEC-WT	Water	Speciated Oil and Grease-Gravimetric	APHA 5520 B
<p>The procedure involves an extraction of the entire water sample with hexane. Sample speciation into mineral and animal/vegetable fractions is achieved via silica gel separation and is then determined gravimetrically.</p>			
P-T-COL-WT	Water	Total P in Water by Colour	APHA 4500-P PHOSPHORUS
<p>This analysis is carried out using procedures adapted from APHA Method 4500-P "Phosphorus". Total Phosphorus is determined colourimetrically after persulphate digestion of the sample.</p>			
PAH-SUM-CALC-WT	Water	TOTAL PAH's	CALCULATION
<p>Total PAH represents the sum of all PAH analytes reported for a given sample. Note that regulatory agencies and criteria differ in their definitions of Total PAH in terms of the individual PAH analytes to be included.</p>			
PAH-WT	Water	Polyaromatic Hydrocarbons (PAHs)	SW846 8270

Reference Information

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Method Reference**
<p>Aqueous samples, fortified with surrogates, are extracted using liquid/liquid extraction technique. The sample extracts are concentrated and then analyzed using GC/MS. Results for benzo(b) fluoranthene may include contributions from benzo(j)fluoranthene, if also present in the sample.</p>			
PCB-WT	Water	Polychlorinated Biphenyls	EPA 8082
<p>PCBs are extracted from an aqueous sample at neutral pH with aliquots of dichloromethane using a modified separatory funnel technique. The extracts are analyzed by GC/MSD.</p>			
PH-WT	Water	pH	APHA 4500 H-Electrode
<p>Water samples are analyzed directly by a calibrated pH meter.</p>			
<p>Analysis conducted in accordance with the Protocol for Analytical Methods Used in the Assessment of Properties under Part XV.1 of the Environmental Protection Act (July 1, 2011). Holdtime for samples under this regulation is 28 days</p>			
PHENOLS-4AAP-WT	Water	Phenol (4AAP)	EPA 9066
<p>An automated method is used to distill the sample. The distillate is then buffered to pH 9.4 which reacts with 4AAP and potassium ferricyanide to form a red complex which is measured colorimetrically.</p>			
SO4-IC-N-WT	Water	Sulfate in Water by IC	EPA 300.1 (mod)
<p>Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.</p>			
SOLIDS-TSS-WT	Water	Suspended solids	APHA 2540 D-Gravimetric
<p>A well-mixed sample is filtered through a weighed standard glass fibre filter and the residue retained is dried in an oven at 104–1°C for a minimum of four hours or until a constant weight is achieved.</p>			
TKN-F-WT	Water	TKN in Water by Fluorescence	J. ENVIRON. MONIT., 2005,7,37-42,RSC
<p>Total Kjeldahl Nitrogen is determined using block digestion followed by Flow-injection analysis with fluorescence detection</p>			
VOC-ROU-HS-WT	Water	Volatile Organic Compounds	SW846 8260
<p>Aqueous samples are analyzed by headspace-GC/MS.</p>			
XYLENES-SUM-CALC-WT	Water	Sum of Xylene Isomer Concentrations	CALCULATION
<p>Total xylenes represents the sum of o-xylene and m&p-xylene.</p>			
<hr/> <p>**ALS test methods may incorporate modifications from specified reference methods to improve performance.</p> <hr/>			
<p>Chain of Custody Numbers:</p> <hr/>			
<p><i>The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:</i></p> <hr/>			
Laboratory Definition Code	Laboratory Location		
WT	ALS ENVIRONMENTAL - WATERLOO, ONTARIO, CANADA		

Reference Information

L2585834 CONT'D....
Job Reference: 21-067
PAGE 22 of 22
19-MAY-21 09:46 (MT)

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to, fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guideline limits are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 1 of 20

Client: Grounded Engineering Inc
12 Banigan Drive
Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
625-BIS-2-PHTH-WT								
	Water							
Batch	R5457563							
WG3533089-2	LCS							
Bis(2-ethylhexyl)phthalate			121.1		%		50-140	14-MAY-21
WG3533089-1	MB							
Bis(2-ethylhexyl)phthalate			<2.0		ug/L		2	14-MAY-21
Surrogate: 2-fluorobiphenyl			66.4		%		40-130	14-MAY-21
Surrogate: p-Terphenyl d14			111.6		%		40-130	14-MAY-21
625-DNB-PHTH-WT								
	Water							
Batch	R5457563							
WG3533089-2	LCS							
Di-n-butylphthalate			113.3		%		50-150	14-MAY-21
WG3533089-1	MB							
Di-n-butylphthalate			<1.0		ug/L		1	14-MAY-21
Surrogate: 2-Fluorobiphenyl			66.4		%		40-130	14-MAY-21
Surrogate: p-Terphenyl d14			111.6		%		40-130	14-MAY-21
BOD-C-WT								
	Water							
Batch	R5458772							
WG3532885-2	DUP	L2585458-1						
BOD Carbonaceous		7.8	8.0		mg/L	1.5	30	11-MAY-21
WG3532885-3	LCS							
BOD Carbonaceous			103.5		%		85-115	11-MAY-21
WG3532885-1	MB							
BOD Carbonaceous			<2.0		mg/L		2	11-MAY-21
BOD-WT								
	Water							
Batch	R5458785							
WG3532884-6	DUP	L2585851-1						
BOD		<3.0	<3.0	RPD-NA	mg/L	N/A	30	11-MAY-21
WG3532884-7	LCS							
BOD			102.5		%		85-115	11-MAY-21
WG3532884-5	MB							
BOD			<2.0		mg/L		2	11-MAY-21
BTX-HS-WT								
	Water							
Batch	R5459623							
WG3536576-4	DUP	WG3536576-3						
Benzene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
Ethylbenzene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
m+p-Xylenes		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 2 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
BTX-HS-WT		Water						
Batch	R5459623							
WG3536576-4	DUP	WG3536576-3						
o-Xylene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
Toluene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
WG3536576-1	LCS							
Benzene			101.6		%		70-130	19-MAY-21
Ethylbenzene			105.5		%		70-130	19-MAY-21
m+p-Xylenes			107.7		%		70-130	19-MAY-21
o-Xylene			115.3		%		70-130	19-MAY-21
Toluene			103.6		%		70-130	19-MAY-21
WG3536576-2	MB							
Benzene			<0.50		ug/L		0.5	19-MAY-21
Ethylbenzene			<0.50		ug/L		0.5	19-MAY-21
m+p-Xylenes			<1.0		ug/L		1	19-MAY-21
o-Xylene			<0.50		ug/L		0.5	19-MAY-21
Toluene			<0.50		ug/L		0.5	19-MAY-21
Surrogate: 1,4-Difluorobenzene			100.5		%		50-150	19-MAY-21
Surrogate: 4-Bromofluorobenzene			100.9		%		50-150	19-MAY-21
WG3536576-5	MS	WG3536576-3						
Benzene			101.4		%		50-150	19-MAY-21
Ethylbenzene			105.0		%		50-150	19-MAY-21
m+p-Xylenes			107.2		%		50-150	19-MAY-21
o-Xylene			115.0		%		50-150	19-MAY-21
Toluene			103.2		%		50-150	19-MAY-21
CL2-TOTAL-WT		Water						
Batch	R5455873							
WG3532773-3	DUP	L2585549-1						
Chlorine, Total		0.350	0.360		mg/L	2.8	15	11-MAY-21
WG3532773-2	LCS							
Chlorine, Total			98.2		%		75-125	11-MAY-21
WG3532773-1	MB							
Chlorine, Total			<0.050		mg/L		0.05	11-MAY-21
WG3532773-4	MS	L2585549-1						
Chlorine, Total			N/A	MS-B	%		-	11-MAY-21
CN-TOT-WT		Water						



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 3 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
CN-TOT-WT		Water						
Batch	R5455737							
WG3532538-3	DUP	WG3532538-5						
Cyanide, Total		<0.0020	<0.0020	RPD-NA	mg/L	N/A	20	11-MAY-21
WG3532538-2	LCS							
Cyanide, Total			96.1		%		80-120	11-MAY-21
WG3532538-1	MB							
Cyanide, Total			<0.0020		mg/L		0.002	11-MAY-21
WG3532538-4	MS	WG3532538-5						
Cyanide, Total			88.6		%		70-130	11-MAY-21
CR-CR6-IC-WT		Water						
Batch	R5456236							
WG3532698-4	DUP	WG3532698-3						
Chromium, Hexavalent		<0.00050	<0.00050	RPD-NA	mg/L	N/A	20	11-MAY-21
WG3532698-2	LCS							
Chromium, Hexavalent			102.1		%		80-120	11-MAY-21
WG3532698-1	MB							
Chromium, Hexavalent			<0.00050		mg/L		0.0005	11-MAY-21
WG3532698-5	MS	WG3532698-3						
Chromium, Hexavalent			101.4		%		70-130	11-MAY-21
EC-WW-MF-WT		Water						
Batch	R5456430							
WG3532402-3	DUP	L2585779-2						
E. Coli		2	<2	RPD-NA	CFU/100mL	N/A	65	11-MAY-21
WG3532402-1	MB							
E. Coli			0		CFU/100mL		1	11-MAY-21
F-IC-N-WT		Water						
Batch	R5457120							
WG3533744-10	DUP	L2585390-5						
Fluoride (F)		0.112	0.111		mg/L	1.2	20	12-MAY-21
WG3533744-7	LCS							
Fluoride (F)			102.2		%		90-110	12-MAY-21
WG3533744-6	MB							
Fluoride (F)			<0.020		mg/L		0.02	12-MAY-21
WG3533744-9	MS	L2585390-5						
Fluoride (F)			99.2		%		75-125	12-MAY-21
HG-T-CVAA-WT		Water						



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 4 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
HG-T-CVAA-WT		Water						
Batch	R5456856							
WG3533406-4	DUP	WG3533406-3						
Mercury (Hg)-Total		<0.0000050	<0.0000050	RPD-NA	mg/L	N/A	20	13-MAY-21
WG3533406-2	LCS							
Mercury (Hg)-Total			104.0		%		80-120	13-MAY-21
WG3533406-1	MB							
Mercury (Hg)-Total			<0.0000050		mg/L		0.000005	13-MAY-21
WG3533406-6	MS	WG3533406-5						
Mercury (Hg)-Total			104.3		%		70-130	13-MAY-21
MET-T-CCMS-WT		Water						
Batch	R5455629							
WG3532214-4	DUP	WG3532214-3						
Aluminum (Al)-Total		0.355	0.331		mg/L	6.9	20	11-MAY-21
Antimony (Sb)-Total		<0.0010	<0.0010	RPD-NA	mg/L	N/A	20	11-MAY-21
Arsenic (As)-Total		<0.0010	<0.0010	RPD-NA	mg/L	N/A	20	11-MAY-21
Barium (Ba)-Total		0.0350	0.0342		mg/L	2.2	20	11-MAY-21
Beryllium (Be)-Total		<0.0010	<0.0010	RPD-NA	mg/L	N/A	20	11-MAY-21
Bismuth (Bi)-Total		<0.00050	<0.00050	RPD-NA	mg/L	N/A	20	11-MAY-21
Boron (B)-Total		<0.10	<0.10	RPD-NA	mg/L	N/A	20	11-MAY-21
Cadmium (Cd)-Total		<0.000050	<0.000050	RPD-NA	mg/L	N/A	20	11-MAY-21
Calcium (Ca)-Total		64.4	62.7		mg/L	2.8	20	11-MAY-21
Chromium (Cr)-Total		0.0051	0.0052		mg/L	1.9	20	11-MAY-21
Cobalt (Co)-Total		<0.0010	<0.0010	RPD-NA	mg/L	N/A	20	11-MAY-21
Copper (Cu)-Total		<0.0050	<0.0050	RPD-NA	mg/L	N/A	20	11-MAY-21
Iron (Fe)-Total		0.42	0.40		mg/L	4.3	20	11-MAY-21
Lead (Pb)-Total		<0.00050	<0.00050	RPD-NA	mg/L	N/A	20	11-MAY-21
Lithium (Li)-Total		<0.010	<0.010	RPD-NA	mg/L	N/A	20	11-MAY-21
Magnesium (Mg)-Total		9.60	9.34		mg/L	2.7	20	11-MAY-21
Manganese (Mn)-Total		0.0435	0.0449		mg/L	3.0	20	11-MAY-21
Molybdenum (Mo)-Total		0.00861	0.00827		mg/L	4.0	20	11-MAY-21
Nickel (Ni)-Total		<0.0050	<0.0050	RPD-NA	mg/L	N/A	20	11-MAY-21
Phosphorus (P)-Total		<0.50	<0.50	RPD-NA	mg/L	N/A	20	11-MAY-21
Potassium (K)-Total		19.0	18.7		mg/L	1.3	20	11-MAY-21
Selenium (Se)-Total		0.00070	0.00065		mg/L	6.8	20	11-MAY-21
Silicon (Si)-Total		2.9	2.8		mg/L	3.0	20	11-MAY-21
Silver (Ag)-Total		<0.00050	<0.00050	RPD-NA	mg/L	N/A	20	11-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 5 of 20

Client: Grounded Engineering Inc
12 Banigan Drive
Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
MET-T-CCMS-WT		Water						
Batch	R5455629							
WG3532214-4	DUP	WG3532214-3						
Sodium (Na)-Total		78.2	76.5		mg/L	2.1	20	11-MAY-21
Strontium (Sr)-Total		0.411	0.406		mg/L	1.2	20	11-MAY-21
Sulfur (S)-Total		31.2	30.0		mg/L	4.1	20	11-MAY-21
Thallium (Tl)-Total		<0.00010	<0.00010	RPD-NA	mg/L	N/A	20	11-MAY-21
Tin (Sn)-Total		<0.0010	<0.0010	RPD-NA	mg/L	N/A	20	11-MAY-21
Titanium (Ti)-Total		0.0118	0.0116		mg/L	2.0	20	11-MAY-21
Tungsten (W)-Total		<0.0010	<0.0010	RPD-NA	mg/L	N/A	20	11-MAY-21
Uranium (U)-Total		0.00038	0.00039		mg/L	3.7	20	11-MAY-21
Vanadium (V)-Total		0.0054	0.0051		mg/L	6.1	20	11-MAY-21
Zinc (Zn)-Total		<0.030	<0.030	RPD-NA	mg/L	N/A	20	11-MAY-21
Zirconium (Zr)-Total		<0.0020	<0.0020	RPD-NA	mg/L	N/A	20	11-MAY-21
WG3532214-2	LCS							
Aluminum (Al)-Total			99.9		%		80-120	11-MAY-21
Antimony (Sb)-Total			104.3		%		80-120	11-MAY-21
Arsenic (As)-Total			101.9		%		80-120	11-MAY-21
Barium (Ba)-Total			103.3		%		80-120	11-MAY-21
Beryllium (Be)-Total			97.4		%		80-120	11-MAY-21
Bismuth (Bi)-Total			103.6		%		80-120	11-MAY-21
Boron (B)-Total			94.6		%		80-120	11-MAY-21
Cadmium (Cd)-Total			103.7		%		80-120	11-MAY-21
Calcium (Ca)-Total			98.9		%		80-120	11-MAY-21
Chromium (Cr)-Total			99.9		%		80-120	11-MAY-21
Cobalt (Co)-Total			101.6		%		80-120	11-MAY-21
Copper (Cu)-Total			100.8		%		80-120	11-MAY-21
Iron (Fe)-Total			102.5		%		80-120	11-MAY-21
Lead (Pb)-Total			104.7		%		80-120	11-MAY-21
Lithium (Li)-Total			95.9		%		80-120	11-MAY-21
Magnesium (Mg)-Total			103.6		%		80-120	11-MAY-21
Manganese (Mn)-Total			100.1		%		80-120	11-MAY-21
Molybdenum (Mo)-Total			100.5		%		80-120	11-MAY-21
Nickel (Ni)-Total			100.9		%		80-120	11-MAY-21
Phosphorus (P)-Total			100.8		%		70-130	11-MAY-21
Potassium (K)-Total			101.8		%		80-120	11-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 6 of 20

Client: Grounded Engineering Inc
12 Banigan Drive
Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
MET-T-CCMS-WT		Water						
Batch	R5455629							
WG3532214-2 LCS								
Selenium (Se)-Total			99.1		%		80-120	11-MAY-21
Silicon (Si)-Total			103.3		%		60-140	11-MAY-21
Silver (Ag)-Total			104.5		%		80-120	11-MAY-21
Sodium (Na)-Total			100.9		%		80-120	11-MAY-21
Strontium (Sr)-Total			102.1		%		80-120	11-MAY-21
Sulfur (S)-Total			98.9		%		80-120	11-MAY-21
Thallium (Tl)-Total			104.8		%		80-120	11-MAY-21
Tin (Sn)-Total			103.9		%		80-120	11-MAY-21
Titanium (Ti)-Total			97.4		%		80-120	11-MAY-21
Tungsten (W)-Total			102.6		%		80-120	11-MAY-21
Uranium (U)-Total			110.6		%		80-120	11-MAY-21
Vanadium (V)-Total			101.9		%		80-120	11-MAY-21
Zinc (Zn)-Total			101.5		%		80-120	11-MAY-21
Zirconium (Zr)-Total			101.6		%		80-120	11-MAY-21
WG3532214-1 MB								
Aluminum (Al)-Total			<0.0050		mg/L		0.005	11-MAY-21
Antimony (Sb)-Total			<0.00010		mg/L		0.0001	11-MAY-21
Arsenic (As)-Total			<0.00010		mg/L		0.0001	11-MAY-21
Barium (Ba)-Total			<0.00010		mg/L		0.0001	11-MAY-21
Beryllium (Be)-Total			<0.00010		mg/L		0.0001	11-MAY-21
Bismuth (Bi)-Total			<0.000050		mg/L		0.00005	11-MAY-21
Boron (B)-Total			<0.010		mg/L		0.01	11-MAY-21
Cadmium (Cd)-Total			<0.0000050		mg/L		0.000005	11-MAY-21
Calcium (Ca)-Total			<0.050		mg/L		0.05	11-MAY-21
Chromium (Cr)-Total			<0.00050		mg/L		0.0005	11-MAY-21
Cobalt (Co)-Total			<0.00010		mg/L		0.0001	11-MAY-21
Copper (Cu)-Total			<0.00050		mg/L		0.0005	11-MAY-21
Iron (Fe)-Total			<0.010		mg/L		0.01	11-MAY-21
Lead (Pb)-Total			<0.000050		mg/L		0.00005	11-MAY-21
Lithium (Li)-Total			<0.0010		mg/L		0.001	11-MAY-21
Magnesium (Mg)-Total			<0.0050		mg/L		0.005	11-MAY-21
Manganese (Mn)-Total			<0.00050		mg/L		0.0005	11-MAY-21
Molybdenum (Mo)-Total			<0.000050		mg/L		0.00005	11-MAY-21
Nickel (Ni)-Total			<0.00050		mg/L		0.0005	11-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 7 of 20

Client: Grounded Engineering Inc
12 Banigan Drive
Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
MET-T-CCMS-WT								
	Water							
Batch	R5455629							
WG3532214-1 MB								
Phosphorus (P)-Total			<0.050		mg/L		0.05	11-MAY-21
Potassium (K)-Total			<0.050		mg/L		0.05	11-MAY-21
Selenium (Se)-Total			<0.000050		mg/L		0.00005	11-MAY-21
Silicon (Si)-Total			<0.10		mg/L		0.1	11-MAY-21
Silver (Ag)-Total			<0.000050		mg/L		0.00005	11-MAY-21
Sodium (Na)-Total			<0.050		mg/L		0.05	11-MAY-21
Strontium (Sr)-Total			<0.0010		mg/L		0.001	11-MAY-21
Sulfur (S)-Total			<0.50		mg/L		0.5	11-MAY-21
Thallium (Tl)-Total			<0.000010		mg/L		0.00001	11-MAY-21
Tin (Sn)-Total			<0.00010		mg/L		0.0001	11-MAY-21
Titanium (Ti)-Total			<0.00030		mg/L		0.0003	11-MAY-21
Tungsten (W)-Total			<0.00010		mg/L		0.0001	11-MAY-21
Uranium (U)-Total			<0.000010		mg/L		0.00001	11-MAY-21
Vanadium (V)-Total			<0.00050		mg/L		0.0005	11-MAY-21
Zinc (Zn)-Total			<0.0030		mg/L		0.003	11-MAY-21
Zirconium (Zr)-Total			<0.00020		mg/L		0.0002	11-MAY-21
WG3532214-5 MS		WG3532214-3						
Aluminum (Al)-Total			N/A	MS-B	%		-	11-MAY-21
Antimony (Sb)-Total			105.7		%		70-130	11-MAY-21
Arsenic (As)-Total			101.8		%		70-130	11-MAY-21
Barium (Ba)-Total			N/A	MS-B	%		-	11-MAY-21
Beryllium (Be)-Total			95.6		%		70-130	11-MAY-21
Bismuth (Bi)-Total			103.4		%		70-130	11-MAY-21
Boron (B)-Total			74.4		%		70-130	11-MAY-21
Cadmium (Cd)-Total			100.9		%		70-130	11-MAY-21
Calcium (Ca)-Total			N/A	MS-B	%		-	11-MAY-21
Chromium (Cr)-Total			95.9		%		70-130	11-MAY-21
Cobalt (Co)-Total			101.4		%		70-130	11-MAY-21
Copper (Cu)-Total			96.5		%		70-130	11-MAY-21
Iron (Fe)-Total			N/A	MS-B	%		-	11-MAY-21
Lead (Pb)-Total			103.6		%		70-130	11-MAY-21
Lithium (Li)-Total			79.9		%		70-130	11-MAY-21
Magnesium (Mg)-Total			N/A	MS-B	%		-	11-MAY-21
Manganese (Mn)-Total			N/A	MS-B	%		-	11-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 8 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
MET-T-CCMS-WT								
	Water							
Batch	R5455629							
WG3532214-5 MS		WG3532214-3						
Molybdenum (Mo)-Total			94.9		%		70-130	11-MAY-21
Nickel (Ni)-Total			99.2		%		70-130	11-MAY-21
Phosphorus (P)-Total			108.3		%		70-130	11-MAY-21
Potassium (K)-Total			N/A	MS-B	%		-	11-MAY-21
Selenium (Se)-Total			97.5		%		70-130	11-MAY-21
Silicon (Si)-Total			N/A	MS-B	%		-	11-MAY-21
Silver (Ag)-Total			104.2		%		70-130	11-MAY-21
Sodium (Na)-Total			N/A	MS-B	%		-	11-MAY-21
Strontium (Sr)-Total			N/A	MS-B	%		-	11-MAY-21
Sulfur (S)-Total			N/A	MS-B	%		-	11-MAY-21
Thallium (Tl)-Total			103.2		%		70-130	11-MAY-21
Tin (Sn)-Total			101.0		%		70-130	11-MAY-21
Titanium (Ti)-Total			95.4		%		70-130	11-MAY-21
Tungsten (W)-Total			101.1		%		70-130	11-MAY-21
Uranium (U)-Total			N/A	MS-B	%		-	11-MAY-21
Vanadium (V)-Total			98.0		%		70-130	11-MAY-21
Zinc (Zn)-Total			97.6		%		70-130	11-MAY-21
Zirconium (Zr)-Total			91.8		%		70-130	11-MAY-21
NP,NPE-LCMS-WT								
	Water							
Batch	R5457482							
WG3533128-3 DUP		L2585322-1						
Nonylphenol		<1.0	<1.0	RPD-NA	ug/L	N/A	30	12-MAY-21
Nonylphenol Monoethoxylates		<2.0	<2.0	RPD-NA	ug/L	N/A	30	12-MAY-21
Nonylphenol Diethoxylates		0.18	0.21		ug/L	15	30	12-MAY-21
Octylphenol		<1.0	<1.0	RPD-NA	ug/L	N/A	30	12-MAY-21
Octylphenol Monoethoxylates		<10	<10	RPD-NA	ug/L	N/A	30	12-MAY-21
Octylphenol Diethoxylates		8.7	8.7		ug/L	0.4	30	12-MAY-21
Bisphenol A		0.71	0.78		ug/L	8.9	30	12-MAY-21
WG3533128-2 LCS								
Nonylphenol			86.7		%		75-125	12-MAY-21
Nonylphenol Monoethoxylates			96.8		%		75-125	12-MAY-21
Nonylphenol Diethoxylates			97.1		%		75-125	12-MAY-21
Octylphenol			93.2		%		75-125	12-MAY-21
Octylphenol Monoethoxylates			111.8		%		75-125	12-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 9 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
NP,NPE-LCMS-WT								
	Water							
Batch	R5457482							
WG3533128-2	LCS							
Octylphenol Diethoxylates			105.1		%		75-125	12-MAY-21
Bisphenol A			123.0		%		75-125	12-MAY-21
WG3533128-1	MB							
Nonylphenol			<1.0		ug/L		1	12-MAY-21
Nonylphenol Monoethoxylates			<2.0		ug/L		2	12-MAY-21
Nonylphenol Diethoxylates			<0.10		ug/L		0.1	12-MAY-21
Octylphenol			<1.0		ug/L		1	12-MAY-21
Octylphenol Monoethoxylates			<2.0		ug/L		2	12-MAY-21
Octylphenol Diethoxylates			<0.10		ug/L		0.1	12-MAY-21
Bisphenol A			<0.20		ug/L		0.2	12-MAY-21
WG3533128-4	MS	L2585322-1						
Nonylphenol			116.8		%		50-150	12-MAY-21
Nonylphenol Monoethoxylates			128.0		%		50-150	12-MAY-21
Nonylphenol Diethoxylates			101.3		%		50-150	12-MAY-21
Octylphenol			113.7		%		50-150	12-MAY-21
Octylphenol Monoethoxylates			105.4		%		50-150	12-MAY-21
Octylphenol Diethoxylates			N/A	MS-B	%		-	12-MAY-21
Bisphenol A			98.5		%		50-150	12-MAY-21
OGG-SPEC-WT								
	Water							
Batch	R5457613							
WG3534233-2	LCS							
Oil and Grease, Total			96.9		%		70-130	13-MAY-21
Mineral Oil and Grease			93.3		%		70-130	13-MAY-21
WG3534233-1	MB							
Oil and Grease, Total			<5.0		mg/L		5	13-MAY-21
Mineral Oil and Grease			<2.5		mg/L		2.5	13-MAY-21
P-T-COL-WT								
	Water							
Batch	R5458652							
WG3535029-3	DUP	WG3535029-5						
Phosphorus, Total		0.229	0.230		mg/L	0.4	20	17-MAY-21
WG3535029-2	LCS							
Phosphorus, Total			102.0		%		80-120	17-MAY-21
WG3535029-1	MB							
Phosphorus, Total			<0.0030		mg/L		0.003	17-MAY-21
WG3535029-4	MS	WG3535029-5						



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 10 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
P-T-COL-WT								
	Water							
Batch	R5458652							
WG3535029-4 MS		WG3535029-5						
Phosphorus, Total			N/A	MS-B	%		-	17-MAY-21
PAH-WT								
	Water							
Batch	R5456395							
WG3533111-2 LCS								
Acenaphthene			98.3		%		50-140	12-MAY-21
Acenaphthylene			93.9		%		50-140	12-MAY-21
Anthracene			96.4		%		50-140	12-MAY-21
Benzo(a)anthracene			97.9		%		50-140	12-MAY-21
Benzo(a)pyrene			98.2		%		60-130	12-MAY-21
Benzo(b&j)fluoranthene			105.4		%		60-130	12-MAY-21
Benzo(g,h,i)perylene			116.2		%		50-140	12-MAY-21
Benzo(k)fluoranthene			102.3		%		50-140	12-MAY-21
Chrysene			93.8		%		50-140	12-MAY-21
Dibenz(a,h)anthracene			101.8		%		50-140	12-MAY-21
Fluoranthene			100.2		%		50-140	12-MAY-21
Fluorene			96.8		%		50-140	12-MAY-21
Indeno(1,2,3-cd)pyrene			118.9		%		50-140	12-MAY-21
Naphthalene			88.3		%		50-130	12-MAY-21
Phenanthrene			103.4		%		50-140	12-MAY-21
Pyrene			99.9		%		50-140	12-MAY-21
WG3533111-1 MB								
Acenaphthene			<0.020		ug/L		0.02	12-MAY-21
Acenaphthylene			<0.020		ug/L		0.02	12-MAY-21
Anthracene			<0.020		ug/L		0.02	12-MAY-21
Benzo(a)anthracene			<0.020		ug/L		0.02	12-MAY-21
Benzo(a)pyrene			<0.0050		ug/L		0.005	12-MAY-21
Benzo(b&j)fluoranthene			<0.020		ug/L		0.02	12-MAY-21
Benzo(g,h,i)perylene			<0.020		ug/L		0.02	12-MAY-21
Benzo(k)fluoranthene			<0.020		ug/L		0.02	12-MAY-21
Chrysene			<0.020		ug/L		0.02	12-MAY-21
Dibenz(a,h)anthracene			<0.020		ug/L		0.02	12-MAY-21
Fluoranthene			<0.020		ug/L		0.02	12-MAY-21
Fluorene			<0.020		ug/L		0.02	12-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 11 of 20

Client: Grounded Engineering Inc
12 Banigan Drive
Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
PAH-WT		Water						
Batch	R5456395							
WG3533111-1	MB							
Indeno(1,2,3-cd)pyrene			<0.020		ug/L		0.02	12-MAY-21
Naphthalene			<0.020		ug/L		0.02	12-MAY-21
Phenanthrene			<0.020		ug/L		0.02	12-MAY-21
Pyrene			<0.020		ug/L		0.02	12-MAY-21
Surrogate: Naphthalene d8			88.7		%		60-140	12-MAY-21
Surrogate: Phenanthrene d10			96.3		%		60-140	12-MAY-21
PCB-WT		Water						
Batch	R5456890							
WG3532307-2	LCS							
Aroclor 1242			95.4		%		65-130	13-MAY-21
Aroclor 1248			82.1		%		65-130	13-MAY-21
Aroclor 1254			94.0		%		65-130	13-MAY-21
Aroclor 1260			99.8		%		65-130	13-MAY-21
WG3532307-1	MB							
Aroclor 1242			<0.020		ug/L		0.02	13-MAY-21
Aroclor 1248			<0.020		ug/L		0.02	13-MAY-21
Aroclor 1254			<0.020		ug/L		0.02	13-MAY-21
Aroclor 1260			<0.020		ug/L		0.02	13-MAY-21
Surrogate: Decachlorobiphenyl			105.3		%		50-150	13-MAY-21
Surrogate: Tetrachloro-m-xylene			83.3		%		50-150	13-MAY-21
PH-WT		Water						
Batch	R5457078							
WG3533512-4	DUP	WG3533512-3						
pH		8.09	7.98	J	pH units	0.11	0.2	12-MAY-21
WG3533512-2	LCS							
pH			7.01		pH units		6.9-7.1	12-MAY-21
PHENOLS-4AAP-WT		Water						
Batch	R5459152							
WG3535134-3	DUP	L2585912-9						
Phenols (4AAP)		<0.0010	0.0015	RPD-NA	mg/L	N/A	20	17-MAY-21
WG3535134-2	LCS							
Phenols (4AAP)			97.8		%		85-115	17-MAY-21
WG3535134-1	MB							
Phenols (4AAP)			<0.0010		mg/L		0.001	17-MAY-21
WG3535134-4	MS	L2585912-9						



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 12 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed	
PHENOLS-4AAP-WT									
Water									
Batch R5459152									
WG3535134-4	MS	L2585912-9							
Phenols (4AAP)			106.8		%		75-125	17-MAY-21	
SO4-IC-N-WT									
Water									
Batch R5457120									
WG3533744-10	DUP	L2585390-5							
Sulfate (SO4)			10.6	10.6	mg/L	0.0	20	12-MAY-21	
WG3533744-7	LCS								
Sulfate (SO4)			102.5		%		90-110	12-MAY-21	
WG3533744-6	MB								
Sulfate (SO4)			<0.30		mg/L		0.3	12-MAY-21	
WG3533744-9	MS	L2585390-5							
Sulfate (SO4)			105.8		%		75-125	12-MAY-21	
SOLIDS-TSS-WT									
Water									
Batch R5456790									
WG3533256-3	DUP	L2585878-1							
Total Suspended Solids			223	198	mg/L	12	20	13-MAY-21	
WG3533256-2	LCS								
Total Suspended Solids			103.0		%		85-115	13-MAY-21	
WG3533256-1	MB								
Total Suspended Solids			<3.0		mg/L		3	13-MAY-21	
TKN-F-WT									
Water									
Batch R5458555									
WG3535044-3	DUP	WG3535044-5							
Total Kjeldahl Nitrogen			1.65	1.61	mg/L	2.5	20	17-MAY-21	
WG3535044-2	LCS								
Total Kjeldahl Nitrogen			99.5		%		75-125	17-MAY-21	
WG3535044-1	MB								
Total Kjeldahl Nitrogen			<0.050		mg/L		0.05	17-MAY-21	
WG3535044-4	MS	WG3535044-5							
Total Kjeldahl Nitrogen			98.4		%		70-130	17-MAY-21	
VOC-ROU-HS-WT									
Water									
Batch R5459623									
WG3536576-4	DUP	WG3536576-3							
1,1,1,2-Tetrachloroethane			<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
1,1,2,2-Tetrachloroethane			<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
1,1,1-Trichloroethane			<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 13 of 20

Client: Grounded Engineering Inc
12 Banigan Drive
Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
VOC-ROU-HS-WT								
	Water							
Batch	R5459623							
WG3536576-4	DUP	WG3536576-3						
1,1,2-Trichloroethane		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
1,2-Dibromoethane		<0.20	<0.20	RPD-NA	ug/L	N/A	30	19-MAY-21
1,1-Dichloroethane		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
1,1-Dichloroethylene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
1,2-Dichlorobenzene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
1,2-Dichloroethane		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
1,2-Dichloropropane		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
1,3-Dichlorobenzene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
1,4-Dichlorobenzene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
2-Hexanone		<20	<20	RPD-NA	ug/L	N/A	30	19-MAY-21
Acetone		<20	<20	RPD-NA	ug/L	N/A	30	19-MAY-21
Benzene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
Bromodichloromethane		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21
Bromoform		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21
Bromomethane		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
Carbon Disulfide		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21
Carbon tetrachloride		<0.20	<0.20	RPD-NA	ug/L	N/A	30	19-MAY-21
Chlorobenzene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
Chloroethane		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21
Chloroform		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21
Chloromethane		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21
cis-1,2-Dichloroethylene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
cis-1,3-Dichloropropene		<0.30	<0.30	RPD-NA	ug/L	N/A	30	19-MAY-21
Dibromochloromethane		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21
Dichlorodifluoromethane		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21
Dichloromethane		<2.0	<2.0	RPD-NA	ug/L	N/A	30	19-MAY-21
Ethylbenzene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
m+p-Xylenes		<0.40	<0.40	RPD-NA	ug/L	N/A	30	19-MAY-21
Methyl Ethyl Ketone		<20	<20	RPD-NA	ug/L	N/A	30	19-MAY-21
Methyl Isobutyl Ketone		<20	<20	RPD-NA	ug/L	N/A	30	19-MAY-21
n-Hexane		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
MTBE		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
o-Xylene		<0.30	<0.30		ug/L			19-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 14 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
VOC-ROU-HS-WT								
	Water							
Batch	R5459623							
WG3536576-4	DUP	WG3536576-3						
o-Xylene		<0.30	<0.30	RPD-NA	ug/L	N/A	30	19-MAY-21
Styrene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
Tetrachloroethylene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
Toluene		<0.40	<0.40	RPD-NA	ug/L	N/A	30	19-MAY-21
trans-1,2-Dichloroethylene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
trans-1,3-Dichloropropene		<0.30	<0.30	RPD-NA	ug/L	N/A	30	19-MAY-21
Trichloroethylene		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
Trichlorofluoromethane		<1.0	<1.0	RPD-NA	ug/L	N/A	30	19-MAY-21
Vinyl chloride		<0.50	<0.50	RPD-NA	ug/L	N/A	30	19-MAY-21
WG3536576-1	LCS							
1,1,1,2-Tetrachloroethane			102.8		%		70-130	19-MAY-21
1,1,2,2-Tetrachloroethane			104.9		%		70-130	19-MAY-21
1,1,1-Trichloroethane			102.6		%		70-130	19-MAY-21
1,1,2-Trichloroethane			100.9		%		70-130	19-MAY-21
1,2-Dibromoethane			99.9		%		70-130	19-MAY-21
1,1-Dichloroethane			103.4		%		70-130	19-MAY-21
1,1-Dichloroethylene			105.2		%		70-130	19-MAY-21
1,2-Dichlorobenzene			107.6		%		70-130	19-MAY-21
1,2-Dichloroethane			103.4		%		70-130	19-MAY-21
1,2-Dichloropropane			104.4		%		70-130	19-MAY-21
1,3-Dichlorobenzene			107.4		%		70-130	19-MAY-21
1,4-Dichlorobenzene			107.4		%		70-130	19-MAY-21
2-Hexanone			104.8		%		60-140	19-MAY-21
Acetone			118.9		%		60-140	19-MAY-21
Benzene			101.6		%		70-130	19-MAY-21
Bromodichloromethane			109.1		%		70-130	19-MAY-21
Bromoform			107.2		%		70-130	19-MAY-21
Bromomethane			99.8		%		60-140	19-MAY-21
Carbon Disulfide			100.4		%		70-130	19-MAY-21
Carbon tetrachloride			105.1		%		70-130	19-MAY-21
Chlorobenzene			104.6		%		70-130	19-MAY-21
Chloroethane			118.5		%		70-130	19-MAY-21
Chloroform			105.7		%		70-130	19-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 15 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
VOC-ROU-HS-WT								
	Water							
Batch	R5459623							
WG3536576-1	LCS							
Chloromethane			106.9		%		60-140	19-MAY-21
cis-1,2-Dichloroethylene			105.4		%		70-130	19-MAY-21
cis-1,3-Dichloropropene			99.1		%		70-130	19-MAY-21
Dibromochloromethane			98.4		%		70-130	19-MAY-21
Dichlorodifluoromethane			98.2		%		50-140	19-MAY-21
Dichloromethane			112.2		%		70-130	19-MAY-21
Ethylbenzene			105.5		%		70-130	19-MAY-21
m+p-Xylenes			107.7		%		70-130	19-MAY-21
Methyl Ethyl Ketone			112.5		%		60-140	19-MAY-21
Methyl Isobutyl Ketone			107.2		%		50-150	19-MAY-21
n-Hexane			104.5		%		70-130	19-MAY-21
MTBE			104.1		%		70-130	19-MAY-21
o-Xylene			115.3		%		70-130	19-MAY-21
Styrene			109.6		%		70-130	19-MAY-21
Tetrachloroethylene			99.8		%		70-130	19-MAY-21
Toluene			103.6		%		70-130	19-MAY-21
trans-1,2-Dichloroethylene			110.3		%		70-130	19-MAY-21
trans-1,3-Dichloropropene			98.7		%		70-130	19-MAY-21
Trichloroethylene			103.0		%		70-130	19-MAY-21
Trichlorofluoromethane			104.6		%		60-140	19-MAY-21
Vinyl chloride			110.5		%		60-140	19-MAY-21
WG3536576-2	MB							
1,1,1,2-Tetrachloroethane			<0.50		ug/L		0.5	19-MAY-21
1,1,2,2-Tetrachloroethane			<0.50		ug/L		0.5	19-MAY-21
1,1,1-Trichloroethane			<0.50		ug/L		0.5	19-MAY-21
1,1,2-Trichloroethane			<0.50		ug/L		0.5	19-MAY-21
1,2-Dibromoethane			<0.20		ug/L		0.2	19-MAY-21
1,1-Dichloroethane			<0.50		ug/L		0.5	19-MAY-21
1,1-Dichloroethylene			<0.50		ug/L		0.5	19-MAY-21
1,2-Dichlorobenzene			<0.50		ug/L		0.5	19-MAY-21
1,2-Dichloroethane			<0.50		ug/L		0.5	19-MAY-21
1,2-Dichloropropane			<0.50		ug/L		0.5	19-MAY-21
1,3-Dichlorobenzene			<0.50		ug/L		0.5	19-MAY-21
1,4-Dichlorobenzene			<0.50		ug/L		0.5	19-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 16 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
VOC-ROU-HS-WT								
	Water							
Batch	R5459623							
WG3536576-2 MB								
2-Hexanone			<20		ug/L		20	19-MAY-21
Acetone			<20		ug/L		20	19-MAY-21
Benzene			<0.50		ug/L		0.5	19-MAY-21
Bromodichloromethane			<1.0		ug/L		1	19-MAY-21
Bromoform			<1.0		ug/L		1	19-MAY-21
Bromomethane			<0.50		ug/L		0.5	19-MAY-21
Carbon Disulfide			<1.0		ug/L		1	19-MAY-21
Carbon tetrachloride			<0.20		ug/L		0.2	19-MAY-21
Chlorobenzene			<0.50		ug/L		0.5	19-MAY-21
Chloroethane			<1.0		ug/L		1	19-MAY-21
Chloroform			<1.0		ug/L		1	19-MAY-21
Chloromethane			<1.0		ug/L		1	19-MAY-21
cis-1,2-Dichloroethylene			<0.50		ug/L		0.5	19-MAY-21
cis-1,3-Dichloropropene			<0.30		ug/L		0.3	19-MAY-21
Dibromochloromethane			<1.0		ug/L		1	19-MAY-21
Dichlorodifluoromethane			<1.0		ug/L		1	19-MAY-21
Dichloromethane			<2.0		ug/L		2	19-MAY-21
Ethylbenzene			<0.50		ug/L		0.5	19-MAY-21
m+p-Xylenes			<0.40		ug/L		0.4	19-MAY-21
Methyl Ethyl Ketone			<20		ug/L		20	19-MAY-21
Methyl Isobutyl Ketone			<20		ug/L		20	19-MAY-21
n-Hexane			<0.50		ug/L		0.5	19-MAY-21
MTBE			<0.50		ug/L		0.5	19-MAY-21
o-Xylene			<0.30		ug/L		0.3	19-MAY-21
Styrene			<0.50		ug/L		0.5	19-MAY-21
Tetrachloroethylene			<0.50		ug/L		0.5	19-MAY-21
Toluene			<0.40		ug/L		0.4	19-MAY-21
trans-1,2-Dichloroethylene			<0.50		ug/L		0.5	19-MAY-21
trans-1,3-Dichloropropene			<0.30		ug/L		0.3	19-MAY-21
Trichloroethylene			<0.50		ug/L		0.5	19-MAY-21
Trichlorofluoromethane			<1.0		ug/L		1	19-MAY-21
Vinyl chloride			<0.50		ug/L		0.5	19-MAY-21
Surrogate: 1,4-Difluorobenzene			100.5		%		70-130	19-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 17 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
VOC-ROU-HS-WT								
	Water							
Batch	R5459623							
WG3536576-2 MB								
Surrogate: 4-Bromofluorobenzene			100.9		%		70-130	19-MAY-21
WG3536576-5 MS		WG3536576-3						
1,1,1,2-Tetrachloroethane			103.7		%		50-150	19-MAY-21
1,1,2,2-Tetrachloroethane			107.4		%		50-150	19-MAY-21
1,1,1-Trichloroethane			101.9		%		50-150	19-MAY-21
1,1,2-Trichloroethane			102.8		%		50-150	19-MAY-21
1,2-Dibromoethane			102.7		%		50-150	19-MAY-21
1,1-Dichloroethane			103.1		%		50-150	19-MAY-21
1,1-Dichloroethylene			102.7		%		50-150	19-MAY-21
1,2-Dichlorobenzene			108.2		%		50-150	19-MAY-21
1,2-Dichloroethane			105.5		%		50-150	19-MAY-21
1,2-Dichloropropane			106.8		%		50-150	19-MAY-21
1,3-Dichlorobenzene			107.2		%		50-150	19-MAY-21
1,4-Dichlorobenzene			107.6		%		50-150	19-MAY-21
2-Hexanone			107.6		%		50-150	19-MAY-21
Acetone			121.7		%		50-150	19-MAY-21
Benzene			101.4		%		50-150	19-MAY-21
Bromodichloromethane			111.1		%		50-150	19-MAY-21
Bromoform			109.2		%		50-150	19-MAY-21
Bromomethane			97.0		%		50-150	19-MAY-21
Carbon Disulfide			96.3		%		50-150	19-MAY-21
Carbon tetrachloride			103.7		%		50-150	19-MAY-21
Chlorobenzene			104.9		%		50-150	19-MAY-21
Chloroethane			114.3		%		50-150	19-MAY-21
Chloroform			106.4		%		50-150	19-MAY-21
Chloromethane			99.0		%		50-150	19-MAY-21
cis-1,2-Dichloroethylene			105.9		%		50-150	19-MAY-21
cis-1,3-Dichloropropene			103.1		%		50-150	19-MAY-21
Dibromochloromethane			99.7		%		50-150	19-MAY-21
Dichlorodifluoromethane			85.0		%		50-150	19-MAY-21
Dichloromethane			112.7		%		50-150	19-MAY-21
Ethylbenzene			105.0		%		50-150	19-MAY-21
m+p-Xylenes			107.2		%		50-150	19-MAY-21
Methyl Ethyl Ketone			114.0		%		50-150	19-MAY-21



Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Page 18 of 20

Client: Grounded Engineering Inc
 12 Banigan Drive
 Toronto On M4H1E9

Contact: DEEPAK KANRAJ

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
VOC-ROU-HS-WT								
	Water							
Batch	R5459623							
WG3536576-5 MS		WG3536576-3						
Methyl Isobutyl Ketone			110.2		%		50-150	19-MAY-21
n-Hexane			101.1		%		50-150	19-MAY-21
MTBE			104.1		%		50-150	19-MAY-21
o-Xylene			115.0		%		50-150	19-MAY-21
Styrene			110.2		%		50-150	19-MAY-21
Tetrachloroethylene			97.6		%		50-150	19-MAY-21
Toluene			103.2		%		50-150	19-MAY-21
trans-1,2-Dichloroethylene			109.1		%		50-150	19-MAY-21
trans-1,3-Dichloropropene			103.1		%		50-150	19-MAY-21
Trichloroethylene			102.6		%		50-150	19-MAY-21
Trichlorofluoromethane			100.4		%		50-150	19-MAY-21
Vinyl chloride			103.2		%		50-150	19-MAY-21

Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Client: Grounded Engineering Inc
12 Banigan Drive
Toronto On M4H1E9

Page 19 of 20

Contact: DEEPAK KANRAJ

Legend:

Limit	ALS Control Limit (Data Quality Objectives)
DUP	Duplicate
RPD	Relative Percent Difference
N/A	Not Available
LCS	Laboratory Control Sample
SRM	Standard Reference Material
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ADE	Average Desorption Efficiency
MB	Method Blank
IRM	Internal Reference Material
CRM	Certified Reference Material
CCV	Continuing Calibration Verification
CVS	Calibration Verification Standard
LCSD	Laboratory Control Sample Duplicate

Sample Parameter Qualifier Definitions:

Qualifier	Description
DLHC	Detection Limit Raised: Dilution required due to high concentration of test analyte(s).
DLM	Detection Limit Adjusted due to sample matrix effects (e.g. chemical interference, colour, turbidity).
J	Duplicate results and limits are expressed in terms of absolute difference.
MS-B	Matrix Spike recovery could not be accurately calculated due to high analyte background in sample.
RPD-NA	Relative Percent Difference Not Available due to result(s) being less than detection limit.

Quality Control Report

Workorder: L2585834

Report Date: 19-MAY-21

Client: Grounded Engineering Inc
12 Banigan Drive
Toronto On M4H1E9
Contact: DEEPAK KANRAJ

Page 20 of 20

Hold Time Exceedances:

ALS Product Description	Sample ID	Sampling Date	Date Processed	Rec. HT	Actual HT	Units	Qualifier
Inorganic Parameters							
Total Residual Chlorine	1	10-MAY-21 10:00	11-MAY-21 15:00	0.25	29	hours	EHTR-FM

Legend & Qualifier Definitions:

EHTR-FM: Exceeded ALS recommended hold time prior to sample receipt. Field Measurement recommended.
EHTR: Exceeded ALS recommended hold time prior to sample receipt.
EHTL: Exceeded ALS recommended hold time prior to analysis. Sample was received less than 24 hours prior to expiry.
EHT: Exceeded ALS recommended hold time prior to analysis.
Rec. HT: ALS recommended hold time (see units).

Notes*:
Where actual sampling date is not provided to ALS, the date (& time) of receipt is used for calculation purposes.
Where actual sampling time is not provided to ALS, the earlier of 12 noon on the sampling date or the time (& date) of receipt is used for calculation purposes. Samples for L2585834 were received on 10-MAY-21 13:10.

ALS recommended hold times may vary by province. They are assigned to meet known provincial and/or federal government requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by the US EPA, APHA Standard Methods, or Environment Canada (where available). For more information, please contact ALS.

The ALS Quality Control Report is provided to ALS clients upon request. ALS includes comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against pre-determined data quality objectives to provide confidence in the accuracy of associated test results.

Please note that this report may contain QC results from anonymous Sample Duplicates and Matrix Spikes that do not originate from this Work Order.



www.alsglo



L2585834-COFC

of Custody (COC) / Analytical Request Form

Canada Toll Free: 1 800 668 9878

COC Number: 20 - 888177

Page 1 of 1

Handwritten initials

Report To Contact and company name below will appear on the final report		Reports / Recipients			Turnaround Time (TAT) Requested			AFFIX ALS BARCODE LABEL HERE (ALS use only)												
Company:	Grounded Engineering	Select Report Format:	<input checked="" type="checkbox"/> PDF <input type="checkbox"/> EXCEL <input type="checkbox"/> EDD (DIGITAL)	<input checked="" type="checkbox"/> Routine [R] if received by 3pm M-F - no surcharges apply																
Contact:	Deepak Kaurav	Merge QC/QCI Reports with COA	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A	<input type="checkbox"/> 4 day [P4] if received by 3pm M-F - 20% rush surcharge minimum																
Phone:		<input checked="" type="checkbox"/> Compare Results to Criteria on Report - provide details below if box checked		<input type="checkbox"/> 3 day [P3] if received by 3pm M-F - 25% rush surcharge minimum																
Company address below will appear on the final report		Select Distribution:	<input checked="" type="checkbox"/> EMAIL <input type="checkbox"/> MAIL <input type="checkbox"/> FAX	<input type="checkbox"/> 2 day [P2] if received by 3pm M-F - 50% rush surcharge minimum																
Street:	12 Bannockburn Dr	Email 1 or Fax:	JKaurav@groundedeng.ca	<input type="checkbox"/> 1 day [E] if received by 3pm M-F - 100% rush surcharge minimum																
City/Province:	Toronto ON	Email 2:		<input type="checkbox"/> Same day [E2] if received by 10am M-S - 200% rush surcharge. Additional fees may apply to rush requests on weekends, statutory holidays and non-routine tests																
Postal Code:	M4H 1E9	Email 3:		Date and Time Required for all E&P TATs:																
Invoice To:	Same as Report To <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Invoice Recipients			For all tests with rush TATs requested, please contact your AM to confirm availability.															
	Copy of Invoice with Report <input type="checkbox"/> YES <input type="checkbox"/> NO	Select Invoice Distribution:	<input checked="" type="checkbox"/> EMAIL <input type="checkbox"/> MAIL <input type="checkbox"/> FAX	Analysis Request																
Company:		Email 1 or Fax:		Indicate Filtered (F), Preserved (P) or Filtered and Preserved (F/P) below																
Contact:		Email 2:		NUMBER OF CONTAINERS	SAMPLES ON HOLD				EXTENDED STORAGE REQUIRED	SUSPECTED HAZARD (see notes)										
Project Information		Oil and Gas Required Fields (client use)									Indicate Filtered (F), Preserved (P) or Filtered and Preserved (F/P) below Red string for Mississauga station and peel sanitizing containers									
ALS Account # / Quote #:		AFE/Cost Center:	PO#:																	
Job #:	21-067	Major/Minor Code:	Routing Code:																	
PO / AFE:		Requisitioner:																		
LSD:		Location:																		
ALS Lab Work Order # (ALS use only):	L2585834	ALS Contact:																		
		Sampler:																		
ALS Sample # (ALS use only):		Sample Identification and/or Coordinates (This description will appear on the report):	Date (dd-mmm-yy):												Time (hh:mm):	Sample Type:				
		SEW-4F-BH 101	10 May												10:00	GW				

Drinking Water (DW) Samples¹ (client use)		Notes / Specify Limits for result evaluation by selecting from drop-down below (Excel COC only)		SAMPLE RECEIPT DETAILS (ALS use only)			
Are samples taken from a Regulated DW System? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO				Cooling Method: <input type="checkbox"/> NONE <input checked="" type="checkbox"/> ICE <input type="checkbox"/> ICE PACKS <input type="checkbox"/> FROZEN <input checked="" type="checkbox"/> COOLING INITIATED			
Are samples for human consumption/ use? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO				Submission Comments identified on Sample Receipt Notification: <input type="checkbox"/> YES <input type="checkbox"/> NO			
				Cooler Custody Seals Intact: <input type="checkbox"/> YES <input type="checkbox"/> N/A Sample Custody Seals Intact: <input type="checkbox"/> YES <input type="checkbox"/> N/A			
				INITIAL COOLER TEMPERATURES °C		FINAL COOLER TEMPERATURES °C	
				1.4 3.1 4.9		14	
SHIPMENT RELEASE (client use)		INITIAL SHIPMENT RECEPTION (ALS use only)		FINAL SHIPMENT RECEPTION (ALS use only)			
Released by:	MJ	Date:	10 May 2021	Time:	1:10	Received by:	SI
		Date:	10 MAY -21	Time:	13:10	Date:	5/10/21
		Time:		Time:		Time:	17:30

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION
 Failure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY. By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified on the back page of the white - report copy.
 1. If any water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.

APPENDIX F



Excavation Dimensions: 112 m x 90 m
 Section Cut: E-W

P5 Level Finished Floor: Elev. 94± m
 P5 Base of Excavation/Drainage Layer: Elev. 93.5± m


Water Table: Elev. 107.7 m


Q Ground Water = 10,000 L/day (S.F = 2)

Q Rainfall (25mm storm event) = 244,000 L/day

Q Total (Ground Water + Rainfall) = 254,000 L/day

Material Name	Color	KS (m/s)
Fill		1e-05
Glacial Till		4.1e-08
Weathered Bedrock		1e-07
Sound Bedrock		1e-08
Concrete Wall		1e-10



	File	21-067 60 Dundas St E			
	Analysis	Seepage model: Preliminary			
	Ref.				
	RS2 File	21-067 60 Dundas St E Seepage model.slmd	Scale	1:495	Eng

APPENDIX G



SHORT TERM - PERMEABLE SHORING

Excavation Dimensions [m]		Rainfall Data		
N-S	112	Year	2	100
E-W	87	Hour	3	12
Area (m ²)	9744	Depth (mm)	25	94
Perimeter (m)	398	Depth (m)	0.025	0.094
Section		Flow [m ³ /day]	Length [m]	Volume [L/day]
Base		0.009	112	1,008
Sides		0.01	398	3,980
Total				4,988
Factor of Safety		2.0		9,976
Storm Events		Summary	L/day	L/min
2 Year [L/day]	100 Year [L/day]	Groundwater	10,000	6.9
243,600	916,000	Rainfall	244,000	169.4
		Total	254,000	176.4

LONG TERM - DRAINED FOUNDATIONS

Excavation Dimensions [m]		Rainfall Data		
N-S	112	Year	2	100
E-W	90	Hour	3	12
Area (m ²)	10080	Depth (mm)	25	94
Perimeter (m)	404	Depth (m)	0.025	0.094
Section		Flow [m ³ /day]	Length [m]	Volume [L/day]
Base		0.009	112	1,008
Sides		0.01	398	3,980
Total				4,988
Factor of Safety		2.0		9,976
Infiltration [L/day]		Summary	L/day	L/min
20319		Groundwater	10,000	6.9
		Infiltration	21,000	14.6
		Total	31,000	21.5