REGION OF PEEL MULTI-USE DEMAND TABLE

WATER CONNECTION

Connection Point		
300mm watermain on South Service Road		
Pressure zone of connection point		
	Residential	Total
Total equivalent population to be serviced 1)	950	950
Total lands to be serviced (ha)	0.44	0.44

Hydrant Flow Test	
Hydrant Flow Test Location 1	Hydrant Flow Test Location 2
84 S Service Rd, Mississauga, ON L5G 2R9	60 S Service Rd, Mississauga, ON L5G 2R9

	Pressure (kPa)	Flow (In I/s)	Time
Minimum water pressure	410	201	9:55
Maximum water pressure	437	0	9:45

	Water demands		
No.		Prop. Building	
	Demand type	Residential	Total
1	Average day flow (L/s)	3.08	3.08
2	Maximum day flow (L/s)	6.16	6.16
3	Peak hour flow (L/s)	9.24	9.24
4	Fire flow (L/s) 2)	83.30	83.30
		Analysis	
5	Maximum day plus fire flow (L/s)	89.46	89.46
6	Peak hour flow (L/s)	9.24	9.24
7	Maximum demand flow (L/s)	89.46	89.46

WASTEWATER CONNECTION						
Connection points ³⁾ :		Ex 250mm sanitary sewer on South Service Road	Total			
Total Lands to be serviced (ha):		0.44	0.44			
Total equivalent	Residential	950	950			
population to be	Retail 5)	0	0			
serviced ¹⁾ :	Total	950	950			
8 Wastewater Sewer Effluent (m³/s):		0.016	0.016			

¹⁾ Please refer to design criteria for population equivencies

²⁾ Please reference the Fire Underwriters Survey Document

 $^{^{\}rm 3)}$ Please specify the connection point (was tewater line or manhole ID

⁴⁾ Please complete as many uses are necessary for the development.

⁵⁾ Retail flows determined based on floor area per OBC occupancy. Refer to attached calculations.