



LEGEND

EP - EDGE OF PAVEMENT
 CB - CATCH BASIN
 CURB - CURB OR CURB AND GUTTER
 C/L - CENTRELINE
 GAS - GAS MAIN
 HYD - FIRE HYDRANT
 HYDV - FIRE HYDRANT VALVE
 PWV - PRIVATE WATER VALVE
 PL - PROPERTY LINE
 POTL - PARCEL OF TIED LAND
 SL - STREETLIGHT
 SW - SIDEWALK
 SAN - SANITARY SEWER
 STM - STORM SEWER
 UB - UTILITY BOX (HYDRO, TELECOMMUNICATIONS)
 UC - UTILITY CORRIDOR (HYDRO, TELECOMM, GAS, SL)
 UP - UTILITY POLE
 WM - WATERMAIN
 WB - WATERBOX
 VB - VALVEBOX

NOTES

1. HYDRO, TELECOMMUNICATIONS, GAS AND SL CORRIDOR TO HAVE A MINIMUM COVER OF 0.965m.
2. WATERMAIN TO HAVE A MINIMUM COVER OF 1.7m.
3. IF UTILITIES CANNOT BE INSTALLED ACCORDING TO THIS STANDARD THEY ARE TO BE INSTALLED AS CLOSE AS POSSIBLE TO THE PRESCRIBED LOCATION SUBJECT TO THE APPROVAL OF THE TRANSPORTATION AND WORKS DEPARTMENT OF THE CITY OF MISSISSAUGA
4. A 0.4m - 0.6m CLEARANCE MUST BE MAINTAINED BETWEEN CABLES AND HYDRANTS.
5. A 0.3m CLEARANCE MUST BE MAINTAINED BETWEEN WATERMAINS AND UTILITY POLES.
6. ROAD WIDTH IS MEASURED FROM FACE OF CURB TO FACE OF CURB AS DEFINED ON OPSD CURB & GUTTER STD. 600.040. PAVEMENT WIDTH IS MEASURED FROM EDGE OF PAVEMENT (EP) TO EDGE OF PAVEMENT (EP).
7. FOR LOCATION OF GAS MAIN WITHIN UTILITY CORRIDOR REFER TO STD. 22II.280
8. HYDRO TRANSFORMER MUST BE LOCATED AT A MINIMUM OF 3.1m FROM ANY DOORS AND/OR WINDOWS
9. SIDEWALK DETAIL MUST BE AODA COMPLIANT.
10. FOR DRIVEWAY ENTRANCE DETAIL REFER TO STD 22II.158.

METRIC
 ALL DIMENSIONS IN METRES



MISSISSAUGA

PRIVATE ROAD CROSS SECTION FOR A COMMON ELEMENT CONDOMINIUM WITH OFF-STREET PARKING

| | | | |
|---------------------|---|--------------|-----------------------|
| EFF. DATE Feb. 2011 | | SCALE N.T.S. | |
| REV. | I | Dec. 2015 | STANDARD No. 22II.155 |