



1 DC5-OVERALL ROOF PLAN
 A121 Scale: 1 : 500

A121 ROOF PLAN NOTES

- 301 SINGLE-PLY TPO ROOF (R-30 MIN.) - 100% OF THE ROOFING AREA WILL HAVE A TPO MEMBRANE THAT COMPLIES WITH THE REQUIREMENT OF A MINIMUM SOLAR REFLECTANCE INDEX (SRI) OF 82 FOR INDUSTRIAL BUILDINGS (AS PER COOL ROOF ALTERNATIVE TO THE GREEN ROOF REQUIREMENTS FOR INDUSTRIAL BUILDINGS), 80 ml REINFORCED TPO MEMBRANE. REFER TO SPEC FOR ADHERED AND MECHANICAL FASTEN ROOFING SYSTEM. WHITE.
- 303 TPO MEMBRANE WALKING PADS.
- 305 COORDINATE LOCATION OF UNIT CENTRED BETWEEN JOISTS.
- 306 CONTROL FLOW ROOF DRAINS. SEE MECH DRAWINGS.
- 307 ROOFTOP UNIT. SEE MECH. DRAWINGS. PROVIDE SLOPE INSULATION/CRICKETS AROUND BASE OF ROOF CURB AND SUPPORTING RAIL AS REQUIRED. GC TO COORDINATE LOCATION OF UNIT CENTRE BETWEEN JOIST.
- 308 SLOPED INSULATION CRICKET.
- 309 LINE OF STRUCTURAL FRAMING BELOW DECK (HIDDEN).
- 310 SIGNAGE POSTED ON ROOF ACCESS HATCH TO READ: ALL ROOF DRAINS ARE CONTROL FLOW. THEY ARE TO REMAIN FUNCTIONING IN THIS MANNER.
- 311 ROOF SCREEN.
- 313 ROOF EXPANSIONS JOINT. SEE DETAIL 10A120.01. SEE STRUCTURAL DRAWINGS.
- 314 ROOF ACCESS HATCH FACTORY-ASSEMBLED INSULATED HOLLOW ALUM FRAME AND SKYLIGHT COVER EQUAL TO BILCO TYPE GS. COMPLETE WITH OPERATING, LOCKING AND RELEASE HARDWARE (914mm X 914mm)
- 426 PREFINISHED ALUMINUM COMPOSITE PANEL CANOPY ALUCOBOND SYSTEM SL2000 COLOUR: PVDF 3 SILVER METALLIC.

ROOF LEGEND

- H.P. ROOF HIGH POINT
- L.P. ROOF LOW POINT
- R.D. @ ROOF DRAIN
- S.D. SCUPPER DRAIN
- ROOF HATCH
- ROOFTOP UNIT. SEE MECH. DWGS.
- INSULATION SUMP AT PROPOSED ROOF DRAIN
- BUILT-UP RIGID INSULATION ROOF CRICKET
- FLOW LINE TO DRAIN
- STRUCTURAL FRAMING BELOW ROOF DECK (HIDDEN). SEE STRUCT. DWGS.
- ROOF WALKWAY PADS.

GENERAL ROOF NOTES

- 1 ALL GAS PIPING ON ROOF SHALL BE PAINTED BY MECHANICAL CONTRACTOR.
 - 2 COORDINATE WITH ARCHITECTURAL & MECHANICAL DWGS. FOR ALL ROOF OPENING SIZES & LOCATIONS. FOR ALL MECH. EQUIPMENT, REFER TO MECHANICAL DWGS.
 - 3 ROOF CURBS TO BE PROVIDED FOR ALL MECHANICAL EQUIPMENT THAT ARE NOT SUPPORTED WITH THEIR OWN CURBS.
 - 4 ALL CURBS TO BE BUILT LEVEL.
 - 5 FOR SIZE AND LOCATION OF GAS PIPES, REFER TO MECHANICAL DRAWINGS.
 - 6 INSTALL STEEL BURGLER BARS TO PROTECT ROOF OPENINGS LARGER THAN 12"x12" T.D.
 - 7 ROOF MEMBRANE SUPPLIER TO PROVIDE ROOF MODIFIED BITUMEN WALKWAYS.
 - 8 ALL RECESSED MECHANICAL ROOF WELLS FULLY TAPERED WITH 2% SLOPE TO DRAINS, TYP. ALL DRAIN SUMPS FULLY TAPERED WITH 2% SLOPES TO DRAIN, TYP.
 - 9 NOTE: AT ALL ROOF PERIMETERS AND ALL WALL ROOFS WHERE EQUIPMENT REQUIRES SERVING WITHIN 10' OF ROOF EDGES, INSTALL ROOF EDGE GUARD/TRAVEL RESTRAINT, TYP.
 - 10 ROOF CRICKET SURFACE TO ACHIEVE 1/4" / 12" SLOPE MINIMUM WITH 1/8" / 12" MINIMUM AT VALLEY
 - 11 ALL DOWNSPOUTS COLLECTOR HEADS AND DOWNSPOUTS TO BE PREFINISHED METAL. REF SPECIFICATIONS FOR ADDITIONAL INFORMATION.
- ROOF SYSTEM TYPE:
 SINGLE-PLY TPO ROOF (R30-MIN) - 100% OF THE ROOF SPACE TPO MEMBRANE TO COMPLY WITH THE REQUIREMENTS OF A MINIMUM SOLAR REFLECTANCE INDEX (SRI) OF 82 FOR INDUSTRIAL BUILDINGS (AS PER COOL ROOF ALTERNATIVE TO THE GREEN REQUIREMENTS FOR INDUSTRIAL BUILDINGS).
- *NOTE: ROOF NOT INTENDED TO BE USED FOR STORM WATER STORAGE. BOTTOM OF OVERFLOW SCUPPERS LOCATED MAXIMUM 150mm ABOVE LOW POINT OF ROOF (ROOF DRAIN ELEVATIONS)

REV #	DATE	REVISION TITLE
1	DEC 05, 2025	ISSUED FOR COORDINATION
2	2026-03-25	ISSUED FOR SPA RESUBMISSION

PROJECT NO: 25026
 DRAWN BY: TL
 CHECKED BY: RBC

NOT RELEASED FOR CONSTRUCTION
 RELEASED FOR CONSTRUCTION

0 ARGENTIA ROAD
 MISSISSAUGA, ON
 TOR00394

PROLOGIS
 Prologis Inc. (Canada)
 185 The West Mall, Suite 700, Toronto
 647-258-2600

https://www.prologis.com

SHEET TITLE:
BUILDING DC5 - OVERALL ROOF PLAN

SEAL: ARCHITECTS
 ALY HARDY
 LICENCE 6768

SHEET NO.
A121