

- SITE ELECTRICAL DIVISION OF SCOPE**
- THIS CONTRACTOR TO INSTALL 8-100mm CONCRETE ENCASED U/G PRIMARY DUCT BANK FROM EXISTING TRANSFORMER FOUNDATION TO NEW TRANSFORMER INSIDE PROPERTY LINE CW 3/8" DIA NYLON PULLROPS OR 3/4" MULE TAPE AS PER ALECTRA INSPECTOR REQUIREMENTS.
  - THIS CONTRACTOR TO INSTALL 4-100mm CONCRETE ENCASED U/G PRIMARY DUCT BANK FROM NEW TRANSFORMER FOUNDATION TO INSIDE PROPERTY LINE CW 3/8" DIA NYLON PULLROPS OR 3/4" MULE TAPE AS PER ALECTRA INSPECTOR REQUIREMENTS.
  - TRANSFORMER CONCRETE BASE, GROUND RODS, BOLLARDS AS PER ALECTRA STANDARDS TO BE SUPPLIED AND INSTALLED BY THIS ELECTRICAL CONTRACTOR.
  - TRANSFORMER TO BE SUPPLIED AND INSTALLED BY ALECTRA.
  - ALL SECONDARY DUCTS AND COMMUNICATION DUCTS TO BE INSTALLED BY THIS ELECTRICAL CONTRACTOR.
  - CONTACT ALECTRA INSPECTIONS AT 905-283-4120 AND INSPECTIONS-CENTRAL@ALECTRAUTILITIES.COM TO COORDINATE MEETING ON-SITE WITH ALECTRA INSPECTOR TO VERIFY THE TRANSFORMER FOUNDATION, GROUND GRID AND PRIMARY DUCT INSTALLATION.
  - COORDINATION METERING REQUIREMENTS WITH ALECTRA METERING DEPARTMENT SUPERVISOR AT 905-798-2892.
  - ALL DUCT (PRIMARY/SECONDARY DUCT, COMMUNICATION DUCTS, GUARD POST/BOLLARD AND TRANSFORMER VAULT) BY THIS CONTRACTOR.
  - REFER TO CIVIL DRAWINGS FOR ALL POLE MOUNTED LIGHTING CONCRETE BASE DETAILS AND REQUIREMENTS.

- KEY NOTES**
- PROVIDE PROVISIONS FOR E.V. PROVIDE PVC BOX (8"X8") IN GROUND AND 6" AWAY FROM CURB FOR CHARGING 1-2°C (POWER) BACK TO ELECTRICAL ROOM. FINAL LOCATION FOR PVC BOX AND 1-2°C (COMMUNICATION) CW PULLSTRING BACK TO TECH. CLOSET. TO BE CONFIRMED WITH ARCHITECT PRIOR TO ROUGH-IN.


DO NOT SCALE DRAWINGS. OBTAIN INFORMATION INVOLVING ACCURATE DIMENSIONS TO STRUCTURE FROM DIMENSIONS SHOWN ON ARCHITECTURAL AND STRUCTURAL DRAWINGS. OR BY SITE MEASUREMENTS. SITE PLAN LAYOUT TO BE OBTAINED FROM ARCHITECT OR CIVIL ENGINEER. CONSULT GENERAL CONSTRUCTION DRAWINGS AS WELL AS DETAIL DRAWINGS TO BECOME FAMILIAR WITH ALL CONDITIONS AFFECTING THE WORK, AND VERIFY SPACES IN WHICH THE WORK WILL BE INSTALLED.

#	DATE	DESCRIPTION	BY
7	2026-03-02	ISSUED FOR RPA	MR
6	2026-02-27	ISSUED FOR COORDINATION	MR
5	2026-02-20	ISSUED FOR COORDINATION	MR
4	2025-10-08	ISSUED FOR ALECTRA REVIEW	MR
3	2025-09-18	ISSUED FOR ALECTRA REVIEW	MR
2	2025-08-22	ISSUED FOR ALECTRA REVIEW	MR
1	2025-06-30	ISSUED FOR ALECTRA REVIEW	MR

**PROJECT**  
 CHICK-FIL-A  
 ERIN MILLS TC  
 2595 ERIN MILLS PARKWAY,  
 MISSISSUAGA ONTARIO

**DRAWING**  
 ELECTRICAL SITE PLAN

PROJECT NO:  
 25-002-001  
 PROJECT DATE:  
 APR 2025  
 DRAWN BY:  
 U.N.  
 CHECKED BY:  
 M.R.  
 SCALE:  
 1:250



DRAWING NO.  
**E101**